



Guidelines for Home Energy Professionals: 2016 Standard Work Specifications (SWS) Redline Report

Guidelines for Home Energy Professionals Project

National Renewable Energy Laboratory (NREL)

September 2016

**NREL is a national laboratory of the U.S. Department of Energy
Office of Energy Efficiency & Renewable Energy
Operated by the Alliance for Sustainable Energy, LLC**

Contract No. DE-AC36-08GO28308

Introduction

2016 Maintenance Update—Standard Work Specifications (SWS) Redline to address comments received prior to October 31, 2015

A total of 94 comments received on the SWS prior to October 31, 2015, were reviewed and adjudicated by the Health & Safety Committee, the HVAC & Baseload Committee, and the Air Sealing & Infiltration Committee. The resulting updates pertained to the specific details and classification numbers listed in the table on the next page. An accompanying comment spreadsheet, published alongside this redline, details the specific comments and adjudication responses. The reference table also lists all details which were changed during the 2015 Maintenance Update.

The changes represented in this redline version are intended to be integrated into the SWS Online Tool at a future date.

Redline documents can be used as reference by users who are looking for the most up-to-date industry standards. Please note: At this time, WAP grantees are not required to revise their field guides in accordance with the redline documents.

2015 Maintenance Update—SWS Update to Align SWS with the Combustion Appliance Section of ANSI/BPI-1200-S-2015: Standard Practice for Basic Analysis of Buildings

The SWS define the minimum requirements to ensure that the work performed during home energy upgrades is effective, durable, and safe. The SWS can be used as an industry guide for workers, training instructors, homeowners, and program administrators involved in the home performance industry.

To ensure that the SWS are accurate and contain the most up-to-date information, comments are accepted on the SWS. These comments are adjudicated by several committees of experts, as detailed in the “2014 SWS Maintenance Report” on the SWS website.

In 2014, several of the comments received were on Section 2.02: Combustion Safety. At the same time, the Building Performance Institute was updating guidance on combustion safety testing. Rather than adjudicate these comments related to combustion safety, members of the SWS Health & Safety SWS Maintenance Committee decided to wait until BPI finalized their guidance, then align the SWS with BPI’s guidance.

In 2015, BPI-1200 was updated to reflect industry consensus around, among other things, testing of combustion appliances. The “redline” document in this report details edits to the SWS Section 2.02: Combustion Safety as well as Details 5.3003.14 & 15: Heating & Cooling – Forced Air. Blue underlined text is new; red strikethrough has been deleted.

**Details and their Classification Number with Redline Changes
from the 2015 and 2016 Maintenance Updates**

| Classification | Detail |
|-------------------------------------|--|
| 2.0100.1 | Global Worker Safety |
| 2.0201.1 | Combustion Appliance Zone (CAZ) Testing |
| 2.0201.2 | Combustion Safety |
| 2.0201.3 | Combustion Appliance Zone (CAZ) Testing |
| 2.0201.4 | Vented Combustion Appliance Safety Testing |
| 2.0202.1 | Unvented Space Heaters: Propane, Natural Gas, and Kerosene Heaters |
| 2.0203.1 | Combustion Air for Natural Draft Appliances |
| 2.0203.2 | Combustion Flue Gas—Orphaned Water Heaters |
| 2.0203.3 | Draft Regulation—Category I Appliance |
| 2.0203.4 | Combustion Air for Natural Draft Appliances |
| 2.0203.5 | Combustion Flue Gas—Orphaned Water Heaters |
| 2.0203.6 | Draft Regulation—Category I Appliance |
| 2.0203.7 | Combustion Air—Boilers |
| 2.0203.8 | Occupant Education |
| 2.0204.1 | Isolating Combustion Water Heater Closet |
| 2.0204.2 | Isolating Combustion Appliance Rooms (e.g., Boiler Room, Furnace Room, and Generator Room) |
| 2.0205.1 | Gas and Oil-Fired Equipment |
| 2.0299.1 | Combustion Appliance Depressurization Limits Table |
| 2.0401.1 | Air Sealing Moisture Precautions |
| 2.0403.1 | Vented Crawl Spaces—Ground Moisture Barrier |
| 2.0403.2 | Closed Crawl Spaces—Ground Moisture Barriers |
| 2.0601.1 | Knob and Tube Wiring |
| 2.0702.1 | Warranty and Service Agreement |
| 3.1201.1 | Double-Hung Wood Windows |
| 3.1601.8 | Preparation and Mechanical Fastening—Mid and High Rise |
| 3.1802.1 | Roof/Exterior Wall Connection, Including Joints at Roof/Parapet/Wall Connections |
| 4.1001.1 | Non-Insulation Contact (IC) Recessed Light |
| 4.1001.3 | Fireplace Chimney and Combustion Flue Vents |
| 4.1003.1 | Pitched/Vaulted/Cathedralized Ceilings—Loose Fill Over |
| 4.1003.2 | Pitched/Vaulted/Cathedralized Ceilings—Dense Pack Over |
| 4.1004.2 | Preparation for Batt Insulation |
| 4.1005.2 | Accessible Floors—Loose Fill Installation |
| 4.1005.3 | Accessible Floors—Batt Insulation Over Existing Insulation |
| 4.1005.6 | Enclosed Attic Storage Platform Floor—Dense Pack Installation |
| 4.1005.7 | Attic Floor—Preparation and Installation of Spray Polyurethane Foam (SPF) |
| 4.1006.1 | Pull-Down Stairs |
| 4.1006.2 | Access Doors and Hatches |

| | |
|--------------------------------------|--|
| 4.1088.8 | Installation/Correction of Unconditioned Attic Ventilation |
| 4.1102.1 | Open-Cavity Wall Insulation—General |
| 4.1103.1 | Dense Pack Exterior Walls |
| 4.1103.2 | Additional Exterior Wall Cavities |
| 4.1103.4 | Dense Packing Blown Insulation |
| 4.1401.1 | Band/Rim Joists—Spray Polyurethane Foam (SPF) Installation |
| 4.1401.2 | Band/Rim Joists—Insulation other than Spray Polyurethane Foam |
| 4.1402.1 | Closed Crawl Spaces—Wall Insulation |
| 4.1402.2 | Basement Wall Insulation—No Groundwater Leakage |
| 5.3003.2 | Combustion Analysis of Oil-Fired Appliances |
| 5.3003.3 | Evaluating Air Flow |
| 5.3003.5 | Refrigerant Line Inspection |
| 5.3003.14 | Combustion Analysis of Gas-Fired Appliances (LP and Natural Gas) |
| 5.3003.14 | Combustion Analysis of Gas-Fired Appliances (LP and Natural Gas) |
| 5.3003.15 | Combustion Analysis of Oil-Fired Appliances |
| 5.3003.15 | Combustion Analysis of Oil-Fired Appliances |
| 5.3104.2 | Maintenance: Gas Boiler Service Inspection |
| 6.6004.2 | Individual Exhaust Fan Serving Multiple Rooms Within Single Dwelling Unit (All Building Types) |
| 6.6102.3 | Intake for Ventilation Air to Forced Air System Used for Heating or Cooling |
| 6.6201.1 | Installed System Air Flow |
| 6.6202.3 | Airflow Control Devices (All Building Types) |
| 6.6202.9 | Filtration for Fan-Powered (Active) Systems |
| 6.6204.1 | Commissioning Existing Exhaust or Supply Ventilation Systems |
| 6.6205.1 | Manufactured Housing Exhaust-Only Strategies |
| 6.6288.1 | Sound-Rating Limits |
| 7.8003.1 | Lighting Upgrade |
| 7.8102.2 | Storage-Type Appliance |

| | | |
|--|---|---|
| 2.0201.1 Combustion Appliance Zone (CAZ) Testing | | |
| Topic | Combustion Safety | |
| Subtopic | Combustion Safety Testing-General | |
| Desired Outcome | Accurate information about appliance safe operation is gathered | |
| Manufactured Housing, Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0201.1a Assessment | <p>Emergency problems (e.g., gas leak <u>greater than 10% Lower Explosion Limit (LEL)</u>, ambient CO levels that exceed 7035 ppm) will be communicated clearly and immediately to the <u>customer, the home shall be evacuated, and appropriate emergency services shall be contacted</u>customer and appropriate solutions will be suggested</p> <p><u>Significant problems (e.g., gas leak less than 10% LEL, ambient CO levels that exceed 35 ppm but less than 70 ppm) will be communicated clearly and immediately to the customer and appropriate solutions will be suggested</u></p> <p><u>Examine appliance for signs of damage, misuse, improper repairs, and lack of maintenance</u></p> | Ensure system does not have <u>potentially</u> fatal problems |
| 2.0201.1b Fuel leak detection | Inspect and test for gas or oil leakage at connections of natural gas, propane piping, or oil systems | Detect fuel gas leaks |
| | If leaks are found, immediate action will be taken to notify occupant to help ensure leaks are repaired | Determine and report need for repair |
| | The report will specify repair for leaks and replacement for hazardous or damaged gas or oil connectors and pipes | |
| 2.0201.1c Venting | <u>For oil systems,</u> T he presence and operability of a draft regulator will be verified and tested | Determine if a regulator is present and working |
| | Combustion venting systems will be inspected for damage, leaks, disconnections, inadequate slope, and other safety hazards | Determine whether vent system is in good condition and installed properly |

| | | |
|--|--|---|
| 2.0201.1d Base pressure test | Baseline pressure will be measured in Combustion Appliance Zone (CAZ) with reference to outdoors | Measure pressure difference between combustion zone and the outside under natural conditions |
| 2.0201.1e Depressurization test | CAZ depressurization testing will be administered on all natural draft equipment <u>for all equipment equipped with a draft hood.</u> <u>Depressurization test will include exhaust fans, interior door closure, or duct leakage, or a combination thereof; the test will be done to determine the largest negative pressure per BPI Standard 1200.</u> | <u>Determine worst-case depressurization in combustion zone due to</u> Measure combined effect of <u>mechanical system fans on combustion zone</u> |
| 2.0201.1f Spillage test | Appliance spillage testing will be administered on natural draft appliances and shall not exceed 2 minutes | Detect excessive spillage of combustion gases |
| 2.0201.1g Carbon monoxide (CO) test in appliance vent | CO will be tested for in undiluted flue gases of combustion appliances For CO levels exceeding 100 ppm as measured or 200 ppm air free measurement, service will be provided to reduce CO to below these levels (unless CO measurement is within manufacturer specifications) If the outlet of the exhaust is accessible, include a CO test on all sealed combustion and power-vented appliances (without atmospheric chimneys) | Measure CO and report excessive levels |
| 2.0201.1h Final test out | Final combustion testing will be conducted at project completion to ensure compliance with the above specifications | Ensure safe operation of combustion appliance within the whole house system after any repair project |

| | | |
|--|---|---|
| 2.0201.2 | Combustion Safety – Make-up Air | |
| Topic | Combustion Safety | |
| Subtopic | Combustion Safety Testing -General | |
| Desired Outcome | Buildup of dangerous combustion byproducts in the living space prevented | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | |
| Single-Family Homes, Manufactured Housing | | |
| | Title | Specification(s) |
| 2.0201.2a | Outside combustion make-up air | Where applicable, combustion air will be provided from the outside and installed in accordance with the 2012 IRC for the type of appliance installed |
| | | Prevent combustion byproducts from entering the house |
| 2.0201.2b | New appliances | <u>If replacing appliances, a sealed-combustion, direct-vent appliance will be installed if possible.</u> New appliances will be installed in accordance with manufacturer specifications, the 2012 IRC G2427.8 , and additional applicable codes |
| | | Prevent combustion byproducts from entering the house |
| | | Replacement equipment venting will be assessed to ensure other existing equipment is not adversely affected |
| 2.0201.2c | CO detection and warning equipment | CO detection or warning equipment will be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in accordance with ASHRAE 62.2 and authority having local jurisdiction |
| | | Alert occupant to CO exposure |
| | | <u>Installation will be accomplished by a licensed electrician when required by local code</u> |
| 2.0201.2d | Gas ovens | Gas ovens will be tested for CO |
| | | Ensure clean burn of gas ovens |
| | | A clean and tune will be conducted if measured CO in the undiluted flue gases of the oven vent at steady state exceeds 200 ppm or 800 <u>225</u> ppm by air-free measurement <u>as measured</u> |
| 2.0201.2e | Gas range burners | Specify clean and tune if the flame has any discoloration, flame impingement, or an irregular pattern, or if burners are visibly dirty, corroded, or bent |
| | | Ensure clean burn and operation of gas range burners |
| 2.0201.2f | Solid fuel burning appliances | If the solid fuel burning appliance is the primary heat source and has signs of structural failure replace solid fuel burning appliance with UL-listed and EPA - certified appliances if the existing appliance is not UL-listed |
| | | Ensure safe operations of solid fuel burning appliances |

| | | |
|-----------------------------|--------------|-------------------------|
| Manufactured Housing | | |
| | Title | Specification(s) |
| | | Objective(s) |

| | | |
|---|--|---|
| 2.0201.2a Outside combustion makeup air | Combustion air will be provided from the outside and, where applicable, in accordance with the 2012 IRC for the type of appliance installed | Prevent combustion byproducts from entering the house |
| 2.0201.2b New appliances | <p>If replacing appliances, a sealed combustion, direct-vent appliance will be installed if possible. New appliance will be installed in accordance with manufacturer specifications, 2012 IRC G2427.8, and additional applicable codes</p> <hr/> <p>Replacement equipment venting will be assessed to ensure other existing equipment is not adversely affected</p> | Prevent combustion byproducts from entering the house |
| 2.0201.2c CO detection and warning equipment | <p>CO detection or warning equipment will be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in accordance with ASHRAE 62.2 and authority having local jurisdiction</p> <hr/> <p>Installation will be accomplished by a licensed electrician when required by local code</p> | Alert occupant to CO exposure |
| 2.0201.2d Gas ovens | <p>Gas ovens will be tested for CO</p> <hr/> <p>A clean and tune will be conducted if measured CO in the undiluted flue gases of the oven vent at steady state exceeds 22500 2500 ppm or 800 ppm by air free measurement</p> | Ensure clean burn of gas ovens |
| 2.0201.2e Gas range burners | Specify clean and tune if the flame has any discoloration, flame impingement, an irregular pattern, or if burners are visibly dirty, corroded, or bent | Ensure clean burn and operation of gas range burners |
| 2.0201.2f Solid fuel burning appliances | <p>If the solid fuel burning appliance is the primary heat source and has signs of structural failure replace solid fuel burning appliance with UL-listed and EPA-certified appliances if the existing appliance is not UL-listed Replacement of solid fuel burning appliance with UL-listed and EPA-certified appliances if the existing appliance is not UL-listed or has signs of structural failure</p> | Ensure safe operations of solid fuel-burning appliances |

| | | |
|--|--|--|
| 2.0201.3 | Combustion Appliance Zone (CAZ) Testing | - |
| Topic | Combustion Safety | - |
| Subtopic | Combustion Safety Testing-General | - |
| Desired Outcome | Accurate information about appliance safe operation is gathered | - |
| - | - | - |
| Manufactured Housing | - | - |
| Title | Specification(s) | Objective(s) |
| 2.0201.3a Assessment | Emergency problems (e.g., gas leak, ambient CO levels that exceed 35 ppm) will be communicated clearly and immediately to the customer and appropriate solutions will be suggested | Ensure system does not have fatal problems |
| 2.0201.3b Fuel leak detection | Inspect and test for gas or oil leakage at connections of natural gas, propane piping, or oil systems | Detect fuel gas leaks |
| - | If leaks are found, immediate action will be taken to notify occupant to help ensure leaks are repaired | Determine and report need for repair |
| - | The report will specify repair for leaks and replacement for hazardous or damaged gas or oil connectors and pipes | - |
| 2.0201.3c Venting | The presence and operability of a draft regulator will be verified and tested | Determine if a regulator is present and working |
| - | Combustion venting systems will be inspected for damage, leaks, disconnections, inadequate slope, and other safety hazards | Determine whether vent system is in good condition and installed properly |
| 2.0201.3d Base pressure test | Baseline pressure will be measured in Combustion Appliance Zone (CAZ) with reference to outdoors | Measure pressure difference between combustion zone and the outside under natural conditions |
| 2.0201.3e Depressurization test | CAZ depressurization testing will be administered on all natural draft equipment | Measure combined effect of mechanical system fans on combustion zone |
| 2.0201.3f Spillage test | Appliance spillage testing will be administered on natural draft appliances and shall not exceed 2 minutes | Detect excessive spillage of combustion gases |
| 2.0201.3g Carbon monoxide (CO) test in appliance vent | CO will be tested for in undiluted flue gases of combustion appliances | Measure CO and report excessive levels |
| - | For CO levels exceeding 100 ppm as measured or 200 ppm air-free measurement, service will be provided to reduce CO to below these levels (unless CO measurement is within manufacturer specifications) | - |
| - | If the outlet of the exhaust is accessible, include a CO test on all sealed combustion and power-vented | - |

appliances (without atmospheric chimneys)

2.0201.3h
Final test out

Final combustion testing will be conducted at project completion to ensure compliance with the above specifications

Ensure safe operation of combustion appliance within the whole house system after any repair project

| | | |
|--|--|---|
| 2.0201.4 Vented Combustion Appliance Safety Testing | | |
| Topic | <u>Combustion Safety</u> | |
| Subtopic | <u>Combustion Safety Testing-General</u> | |
| Desired Outcome | <u>Buildup of dangerous combustion byproducts in the living space prevented</u> | |
| Manufactured Housing, Single-family | | |
| Title | Specification(s) | Objective(s) |
| 2.0201.4a Spillage test | <p><u>In conditions with largest negative pressure as determined from Detail 2.0201.1e:</u></p> <p><u>If spillage in a combustion appliance with a warm vent exceeds two minutes during pressure testing, specify measures to mitigate.</u></p> <p><u>If spillage in a combustion appliance with a cold vent exceeds five minutes during pressure testing, specify measures to mitigate.</u><u>If spillage in a furnace in heating mode, or in a water heater, exceeds two minutes during pressure testing, specify measures to mitigate</u></p> <p><u>If spillage in a furnace NOT in heating mode exceeds five minutes during pressure testing, specify measures to mitigate</u></p> | <u>Detect excessive spillage of combustion gases</u> |
| 2.0201.4b Carbon monoxide (CO) test in appliance vent | <p><u>CO will be tested for in undiluted flue gases of combustion appliances</u></p> <hr/> <p><u>In conditions with largest negative pressure as determined from Detail 2.0201.3e:</u></p> <hr/> <p><u>If CO levels exceed 400 ppm air-free measurement in furnaces, service will be provided to reduce CO to below these levels (unless CO measurement is within manufacturer specifications)</u></p> <hr/> <p><u>If CO levels exceed 200 ppm air-free measurement in water heaters or room heaters, service will be provided to reduce CO to below these levels (unless CO measurement is within manufacturer specifications)</u></p> | <u>Measure CO and report excessive levels</u> |
| 2.0201.4c Final test out | <u>Final combustion testing will be conducted at project completion to ensure compliance with the above specifications</u> | <u>Ensure safe operation of combustion appliance within the whole house system after any repair project</u> |

2.0202.1 Unvented Space Heaters: Propane, Natural Gas, and Kerosene Heaters

Topic Combustion Safety
Subtopic Unvented Space Heaters
Desired Outcome Elimination of combustion byproducts

Single-Family Homes

| Title | Specification(s) | Objective(s) |
|---------------------------------|--|---|
| | With the occupant's permission, unvented heaters will be removed except when used as a secondary heat source and when it can be confirmed that the unit is listed to ANSI Z21.11.2 | |
| 2.0202.1a Removal | Units that are not being operated in compliance with ANSI Z21.11.2 should be removed before the retrofit but may remain until a replacement heating system is in place | Eliminate sources of combustion byproduct within a living space |
| | Failure to remove unvented space heaters serving as primary heat sources has the potential to create hazardous conditions and thus any further weatherization services will be re-evaluated in the context of potential indoor air quality risks | |
| 2.0202.1b Occupant education | Occupant will be educated on potential hazards of unvented combustion appliances (primary or secondary) within a living space | Inform occupant about possible hazards associated with combustion byproducts and moisture |

Manufactured Housing

| Title | Specification(s) | Objective(s) |
|---------------------------------|--|---|
| | With the occupant's permission, unvented heaters will be removed except when used as a secondary heat source and when it can be confirmed that the unit is listed to ANSI Z21.11.2 | |
| 2.0202.1a Removal | Units that are not being operated in compliance with ANSI Z21.11.2 should be removed before the retrofit but may remain until a replacement heating system is in place | Eliminate sources of combustion byproduct within a living space |
| | Failure to remove unvented space heaters serving as primary heat sources has the potential to create hazardous conditions, and thus any further weatherization services will be reevaluated in the context of potential indoor air quality risks | |
| 2.0202.1b Occupant education | Occupant will be educated on potential hazards of unvented combustion appliances (primary or secondary) within a living space | Inform occupant about possible hazards associated with combustion byproducts and moisture |

| | | | |
|----------------------------|--|---|--|
| 2.0203.1 | Combustion Air for Natural Draft Appliances | | |
| Topic | Combustion Safety | | |
| Subtopic | Vented Gas Appliances | | |
| Desired Outcome | Sufficient air provided in the Combustion Appliance Zone (CAZ) | | |
| Single-Family Homes | | | |
| | Title | Specification(s) | |
| | | Objective(s) | |
| 2.0203.1a | Required combustion air | The required volume of indoor air will be determined in accordance with 2012 IRC Section G2407.5.1 or G2407.5.2 and authority having jurisdiction, except that where the air infiltration rate is known to be less than 0.40 air changes per hour (ACH), 2012 IRC Section G2407.5.2 will be used | Determine if existing conditions meet the combustion air calculation |
| 2.0203.1b | Additional combustion air (if action is required) | Additional combustion air will be provided in accordance with 2012 IRC G2407 and authority having jurisdiction when necessary to solve spillage problems | Ensure adequate combustion air for operation of the appliance |
| 2.0203.1c | Spillage testing | If spillage in a combustion appliance with a warm vent exceeds two minutes during pressure testing, specify measures to mitigate. If spillage in a combustion appliance with a cold vent exceeds five minutes during pressure testing, specify measures to mitigate. | Detect excessive spillage of combustion gases. |

| 2.0203.2 Combustion Flue Gas—Orphaned Water Heaters | | |
|---|---|--|
| Topic | Combustion Safety | |
| Subtopic | Vented Gas Appliances | |
| Desired Outcome | Flue gases successfully removed from the house | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0203.2a Spillage testing | If spillage in a combustion appliance with a warm vent spillage exceeds two minutes during pressure testing, specify measures to mitigate If spillage in a combustion appliance with a cold vent exceeds five minutes during pressure testing, specify measures to mitigate | Detect excessive spillage of combustion gases Ensure appliance is not spilling longer than two minutes |
| 2.0203.2b Flue gas removal (chimney liner or approved methods) | A chimney liner will be installed in accordance with the 2012 IRC or applicable NFPA standard | Allow water heater to vent properly Prevent damage to the chimney |
| 2.0203.2c Retesting spillage | If a combustion appliance spillage exceeds two minutes during pressure testing, specify measures to mitigate | Ensure appliance is not spilling longer than two minutes with a warm vent |
| 2.0203.2d Required combustion air | The minimum required volume will be 50 cubic feet per 1,000 Btu/h in accordance with 2012 IRC G2407.5.1 and authority having jurisdiction | Determine if existing conditions meet the combustion air calculation |
| 2.0203.2e Additional combustion air (if action is required) | Additional combustion air will be provided in accordance with 2012 IRC G2407 or other authority having jurisdiction | Ensure adequate combustion air for operation of the appliance |
| 2.0203.2f Occupant health and safety | All homes will have a functioning CO alarm If CO levels in interior living spaces exceed outdoor levels, investigate potential sources and take appropriate action to reduce them (e.g., have a qualified professional tune, repair or replace improperly operating combustion appliances; apply weather stripping or conduct air sealing between the garage or crawl space and the home) | Ensure occupant health and safety Ensure indoor CO levels do not exceed outdoor CO levels |
| 2.0203.2g Occupant education | Occupants will be educated on the operation and maintenance of the CO alarm Completed work on combustion appliances and recommended maintenance will be reviewed with occupant Occupant will be provided information regarding the health effects and risk of high CO concentrations; EPA describes possible expanded actions, and offers client education information in an appendix to the protocols | Ensure occupant can operate and maintain installations Inform occupant regarding possible CO hazards - |

| | | |
|---|---|--|
| 2.0203.3 | Draft Regulation—Category I Appliance | - |
| Topic | Combustion Safety | - |
| Subtopic | Vented Gas Appliances | - |
| Desired Outcome | Build-up of flue gasses prevented with proper drafting | - |
| - | - | - |
| Single-Family Homes | - | - |
| Title | Specification(s) | Objective(s) |
| 2.0203.3a Assessment | The presence of an operable draft regulator will be verified | Determine if a draft regulator is present and working and if vent system is in good condition and installed properly |
| - | Combustion venting systems will be inspected for damage, leaks, disconnections, and other safety hazards | - |
| 2.0203.3b Installation (if action is required) | A draft regulator will be installed, if necessary | Install regulator in accordance with manufacturer specifications |
| - | Manufacturer specifications for installation will be followed (e.g., size, type, location) | - |
| 2.0203.3c Retesting spillage | If a combustion appliance spillage exceeds two minutes during pressure testing, specify measures to mitigate | Ensure appliance is not spilling longer than two minutes |
| 2.0203.3d Occupant health and safety | All homes will have a functioning CO alarm | Ensure occupant health and safety |
| - | If CO levels in interior living spaces exceed outdoor levels, potential sources will be investigated and appropriate action taken to reduce them (e.g., have a qualified professional tune, repair, or replace improperly operating combustion appliances; apply weather stripping or conduct air sealing between the garage or crawl space and the home) | Ensure indoor CO levels do not exceed outdoor CO levels |
| 2.0203.3e Occupant education | Occupants will be educated on the operation and maintenance of the CO alarm | Ensure occupant can operate and maintain installations |
| - | Completed work on combustion appliances and recommended maintenance will be reviewed with occupant | Inform occupant regarding possible CO hazards |
| - | Occupant will be provided information regarding the health effects and risk of high CO concentrations; EPA provides possible expanded actions and offers client education information in an appendix to the protocols | - |

| | | |
|---|---|--|
| 2.0203.4 | Combustion Air for Natural Draft Appliances | - |
| Topic | Combustion Safety | - |
| Subtopic | Vented Gas Appliances | - |
| Desired Outcome | Sufficient air provided in the Combustion Appliance Zone (CAZ) | - |
| - | - | - |
| Manufactured Housing | - | - |
| Title | Specification(s) | Objective(s) |
| 2.0203.4a Required combustion air Comment | The required volume of indoor air will be determined in accordance with Section G2407.5.1 or G2407.5.2 and authority having jurisdiction, except where the air infiltration rate is known to be less than 0.40 air changes per hour (ACH), at which time Section G2407.5.2 will be used | Determine if existing conditions meet the combustion air calculation |
| 2.0203.4b Additional combustion air (if action is required) Comment | Additional combustion air will be provided in accordance with 2012 IRC G2407 and authority having jurisdiction | Ensure adequate combustion air for operation of the appliance |
| 2.0203.4c Spillage testing Comment | If a combustion appliance spillage exceeds 2 minutes during pressure testing, specify measures to mitigate | Ensure appliance is not spilling longer than 2 minutes |
| 2.0203.4d Occupant health and safety Comment | All homes will have a functioning CO alarm | Ensure occupant health and safety |
| - | If CO levels in interior living spaces exceed outdoor levels, investigate potential sources and take appropriate action to reduce them (e.g., have a qualified professional tune, repair, or replace improperly operating combustion appliances; apply weatherstripping; or conduct air sealing between the garage or crawl space and the home) | Ensure indoor CO levels do not exceed outdoor CO levels |
| 2.0203.4e Occupant education Comment | Occupants will be educated on the operation and maintenance of the CO alarm | Ensure occupant can operate and maintain installations |
| - | Completed work on combustion appliances and recommended maintenance will be reviewed with occupant | Inform occupant regarding possible CO hazards |
| - | Occupant will be provided information regarding the health effects and risks of high CO concentrations | - |

| | | |
|--|---|--|
| 2.0203.5 | Combustion-Flue-Gas—Orphaned-Water Heaters | - |
| Topic | Combustion-Safety | - |
| Subtopic | Vented-Gas-Appliances | - |
| Desired Outcome | Flue-gasses-successfully-removed-from-the-house | - |
| - | - | - |
| Manufactured Housing | - | - |
| Title | Specification(s) | Objective(s) |
| 2.0203.5a Spillage testingComment | If a combustion appliance spillage exceeds 2 minutes during pressure testing, specify measures to mitigate | Ensure appliance is not spilling longer than 2 minutes |
| 2.0203.5b Retesting spillageComment | If a combustion appliance spillage exceeds 2 minutes during pressure testing, specify measures to mitigate | Ensure appliance is not spilling longer than 2 minutes |
| 2.0203.5c Required combustion airComment | The minimum required volume will be 50 cubic feet per 1,000 Btu/h in accordance with 2012 IRC G2407.5.1 or local authority having jurisdiction | Determine if existing conditions meet the combustion-air calculation |
| 2.0203.5d Additional combustion-air (if action-is required)Comment | Additional combustion-air will be provided in accordance with 2012 IRC G2407 or local authority having jurisdiction | Ensure adequate combustion-air for operation of the appliance |
| 2.0203.5e Occupant health and safetyComment | All homes will have a functioning CO alarm (EPA offers expanded actions) | Ensure occupant health and safety |
| - | If CO levels in interior living spaces exceed outdoor levels, investigate potential sources and take appropriate action to reduce them (e.g., have a qualified professional tune, repair, or replace improperly operating combustion appliances; apply weatherstripping; or conduct air sealing between the garage or crawl space and the home) | Ensure indoor CO levels do not exceed outdoor CO levels |
| 2.0203.5f Occupant educationComment | Occupants will be educated on the operation and maintenance of the CO alarm | Ensure occupant can operate and maintain installations |
| - | Completed work on combustion appliances and recommended maintenance will be reviewed with occupant | Inform occupant regarding possible CO hazards |
| - | Occupant will be provided information regarding the health effects and risks of high CO concentrations | - |

| | | | |
|---|--|---|--|
| 2-0203.6 | Draft Regulation—Category I Appliance | - | - |
| Topic | Combustion Safety | | - |
| Subtopic | Vented Gas Appliances | | - |
| Desired Outcome | Buildup of flue gasses prevented with proper drafting | | - |
| - | - | | - |
| Manufactured Housing | - | | - |
| Title | Specification(s) | | Objective(s) |
| 2-0203.6a Assessment Comment | The presence of an operable draft regulator will be verified | | Determine if a regulator is present and working and if vent system is in good condition and installed properly |
| - | Combustion venting systems will be inspected for damage, leaks, disconnections, and other safety hazards | | - |
| 2-0203.6b Installation (if action is required) Comment | A draft regulator will be installed if necessary | | Install regulator in accordance with manufacturer specifications |
| - | Manufacturer specifications for installation will be followed (e.g., size, type, location) | | - |
| 2-0203.6c Retesting spillage Comment | If a combustion appliance spillage exceeds 2 minutes during pressure testing, specify measures to mitigate | | Ensure appliance is not spilling longer than 2 minutes |
| 2-0203.6d Occupant health and safety Comment | All homes will have a functioning CO alarm; EPA offers expanded actions | | Ensure occupant health and safety |
| - | If CO levels in interior living spaces exceed outdoor levels, potential sources will be investigated and appropriate action taken to reduce them (e.g., have a qualified professional tune, repair, or replace improperly operating combustion appliances; apply weatherstripping; conduct air sealing between the garage or crawl space and the home) | | Ensure indoor CO levels do not exceed outdoor CO levels |
| 2-0203.6e Occupant education Comment | Occupants will be educated on the operation and maintenance of the CO alarm | | Ensure occupant can operate and maintain installations |
| - | Completed work on combustion appliances and recommended maintenance will be reviewed with occupant | | Inform occupant regarding possible CO hazards |
| - | Occupant will be provided information regarding the health effects and risks of high CO concentrations | | - |

| | | |
|-----------------------------|--|---|
| 2.0203.7 | Combustion Air—Boilers | |
| Topic | Combustion Safety | |
| Subtopic | Vented Gas Appliances | |
| Desired Outcome | Amount and quality of combustion air allows for safe and efficient operation of equipment | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0203.7a Combustion air | Combustion air shall be calculated and provided in conformance with the applicable code adopted by the jurisdiction and manufacturer requirements. In instances where conflicts occur between the code and the manufacturer's installation instructions, the more restrictive provisions shall apply (i.e., more air rather than less) In absence of a local code, combustion air shall be calculated and provided in conformance with any of the following: NFPA 54, IFGC, or NFPA 31 | Meet burner combustion air requirements |
| 2.0203.7b Education | Property manager/occupant will be educated on proper operation of combustion air systems | Ensure occupant safety Ensure optimal operation of equipment |

| | | |
|--|--|--|
| 2.0203.8 | <u>Occupant Education</u> | - |
| Topic | <u>Combustion Safety</u> | - |
| Subtopic | <u>Occupant Education</u> | - |
| Desired Outcome | <u>Ensure persistence of resident safety</u> | - |
| - | - | - |
| Single-Family Homes, Manufactured Housing | | |
| Title | <u>Specification(s)</u> | <u>Objective(s)</u> |
| <u>2.0203.8a Occupant health and safety</u> | <u>All homes will have a functioning CO alarm</u> | <u>Ensure occupant health and safety</u> |
| - | <u>If CO levels in interior living spaces exceed outdoor levels, potential sources will be investigated and appropriate action taken to reduce them (e.g., have a qualified professional tune, repair, or replace improperly operating combustion appliances; apply weather stripping or conduct air sealing between the garage or crawl space and the home)</u> | - |
| - | | <u>Ensure indoor CO levels do not exceed outdoor CO levels</u> |
| <u>2.0203.8b Occupant education</u> | <u>Occupants will be educated on the operation and maintenance of the CO alarm</u> | <u>Ensure occupant can operate and maintain installations</u> |
| - | <u>Completed work on combustion appliances and recommended maintenance will be reviewed with occupant</u> | <u>Inform occupant regarding possible CO hazards</u> |
| - | <u>Occupant will be provided information regarding the health effects and risk of high CO concentrations; EPA provides possible expanded actions and offers client education information in an appendix to the protocols</u> | - |

| 2.0204.1 Isolating Combustion Water Heater Closet | | |
|--|--|---|
| Topic | Combustion Safety | |
| Subtopic | Isolation | |
| Desired Outcome | Isolate combustion water heater closet from conditioned space | |
| Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |
| 2.0204.1a Work assessment | Installer prework assessment will be conducted to determine: <ul style="list-style-type: none"> Combustion safety Proper venting Structural integrity Roof leaks Insect infestation Accessibility Number, type, size, and location of penetrations | Ensure combustion appliance is functioning safely Ensure work space is safe and ready for air sealing Verify scope of work |
| 2.0204.1b Air seal closet | When the water heater closet contains a heater that is not sealed combustion or power vented, the closet will be isolated/separated from the rest of the home through air sealing with fire-rated materials, if feasible Avoiding frozen pipes must be considered without creating an additional utility burden (e.g., heat tape) | Prevent combustion gases from entering living area and minimize extension of interior pressures caused by exhaust fan, dryers, and interior door closure into the water heater closet |
| 2.0204.1c Materials | Only noncombustible materials will be used in contact with chimneys, vents, and flues | Prevent a fire hazard |
| 2.0204.1d Post-work testing/verification | Blower door assisted zonal pressure diagnostics will be used to verify isolation has been achieved | Prevent combustion gases from entering living area |

| | | |
|--|---|--|
| 2.0204.2 Isolating Combustion Appliance Rooms (e.g., Boiler Room, Furnace Room, and Generator Room) | | |
| Topic | Combustion Safety | |
| Subtopic | Isolation | |
| Desired Outcome | Effective air barrier between the combustion appliance room and all other spaces of the building | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0204.2a Pre-inspection | <p>Hazardous materials stored in mechanical rooms with air handlers or combustion appliances (e.g., boilers, furnaces) will be identified and removed; operators will be educated on the dangers of storing hazardous materials in these areas</p> <p>Repairs necessary to stabilize work areas and protect or preserve integrity of energy improvement will be completed before subject work begins</p> <p>Mechanical room doors in a fire-rated wall will be closed; problems that cause doors to be blocked open will be determined and resolved</p> | <p>Eliminate existing storage hazards and prevent future dangerous storage occurrences</p> <p>Repair or address moisture, pest, and structure-related issues</p> <p>Provide a safe and stable work environment</p> |
| 2.0204.2b Identification of penetrations | Penetrations will be identified using visual inspections, infrared thermography, smoke, and/or pressure tests [ASTM E1186-03 (2009)] | Locate air leakage pathways to repair |
| 2.0204.2c Preparation | <p>Health and safety concerns will be addressed for occupants, workers, and repair materials in accordance with OSHA standards (OSHA 1926, 1910)</p> <p>The area will be prepared and isolated in accordance with health and safety standards for the application and materials (e.g., extreme temperatures, lead, asbestos, carbon monoxide)</p> <p>Work lighting, work platform, and adequate ventilation will be provided</p> | <p>Provide a safe work environment</p> <p>Provide a safe indoor environmental quality (IEQ) work environment</p> <p>Provide effective repair access</p> |
| 2.0204.2d Sealant and materials selection | <p>Sealants and materials will be compatible with their intended surfaces and applied in accordance with manufacturer specifications</p> <p>Selection will be durable, pest resistant, and have a weather-appropriate seal</p> <p>Indoor sealants will be low VOC products that meet independent testing and verification protocols, such as Green Seal GS-36, "GREENGUARD Children and Schools," or comparable certifications</p> <p>Fire-rated assemblies will be sealed by qualified workers, using materials and sealants permitted by the authority having jurisdiction, and in accordance with adopted building codes</p> | <p>Ensure sealants and materials meet or exceed the performance characteristics required of the assembly (e.g., fire rating)</p> <p>Prevent intrusion of moisture and pests into the sealed assembly</p> <p>Prevent exposing workers or occupants to excessive VOC levels</p> <p>Provide a durable and effective isolation of the identified compartmentalized space</p> |

Mechanical and boiler room enclosures may need to be fire-rated assemblies. Materials will be rated for application in approved details; for example, the annular space around a pipe penetration through a fire-rated wall can usually be sealed using mineral wool fire safing sealed with a coating of flexible fire dam material Sealants and materials will be continuous and meet fire resistance rated assembly specifications

2.0204.2e
Verification

Repairs will be verified using visual inspections, infrared thermography, smoke, and/or pressure tests [ASTM E1186-03 (2009)]

Ensure quality and effectiveness of air sealing

| | | |
|---------------------------------|---|---|
| 2.0205.1 | Gas and Oil-Fired Equipment | |
| Topic | Combustion Safety | |
| Subtopic | Gas and Oil-Fired Equipment | |
| Desired Outcome | Combustion products are properly vented to the outdoors | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0205.1a Combustion air | <p>Combustion air shall be calculated and provided in conformance with the applicable code adopted by the jurisdiction, and manufacturer installation requirements</p> <p>In instances where conflicts occur between the code and the manufacturer's installation instructions, the more restrictive provisions shall apply</p> <p>In absence of a local code, combustion air shall be calculated and provided in conformance with any of the following: NFPA 54, IFGC, or NFPA 31</p> | <p>Do not damage building</p> <p>Protect workers and occupants from injury</p> |
| 2.0205.1b Installation | <p>Venting systems will be installed considering proper material, pitch, common venting, chimney liner, clearance, total equivalent length, and termination in accordance with the applicable code adopted by the jurisdiction and manufacturer installation requirements</p> <p>In instances where conflicts occur between the code and the manufacturer's installation instructions, the more restrictive provisions shall apply</p> <p>In absence of local code, combustion byproducts shall be removed in accordance with any of the following: NFPA 54, IFGC, or NFPA 31</p> | <p>Exhaust combustion products to the outdoors</p> <p>Protect building from damage</p> <p>Protect workers and occupants from injury</p> |
| 2.0205.1c Orphaned equipment | <p>Existing vent system or chimney will be resized or relined in accordance with the applicable code adopted by the jurisdiction when one or more common vented appliances are removed</p> <p>In absence of local code, combustion byproducts shall be removed in accordance with any of the following: NFPA 54, IFGC, or NFPA 31</p> | <p>Exhaust combustion products to the outdoors</p> <p>Protect building from damage</p> <p>Protect workers and occupants from injury</p> |

| 2.0299.1 Combustion Appliance Depressurization Limits Table - | | |
|--|---|--|
| Topic | Combustion Safety | |
| Subtopic | Additional Resources | |
| Desired Outcome | Ensure appliances meet manufacturer's certified negative pressure tolerance rating | |
| Single-Family Homes, Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |
| 2.0299.1a Atmospheric water heater only (Category I, natural draft), open-combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit—2 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1b Atmospheric water heater (Category I, natural draft) and atmospheric furnace (Category I, natural draft), common-vented, open-combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit—3 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1c Gas furnace or boiler, Category I or Category I fan-assisted, open-combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit—5 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1d Oil or gas unit with power burner, low or high static pressure burner, open combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit—5 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1e Closed, controlled wood-burning appliances | Manufacturer's certified negative pressure tolerance rating: Limit—7 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1f Induced-draft appliances (fan at point of exit at wall), Category I with induced draft, open-combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit—15 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |

| | | |
|---|--|---|
| 2.0299.1g Pellet stoves with exhaust fan and sealed vent | Manufacturer's certified negative pressure tolerance rating: Limit 15 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1h Gas appliances, Category III vented through the wall, forced draft, open- combustion appliances | Manufacturer's certified negative pressure tolerance rating: Limit 15 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |
| 2.0299.1i Direct vent, sealed combustion appliances with forced draft | Manufacturer's certified negative pressure tolerance rating: Limit 25 pascals - | Ensure appliances meet manufacturer's certified negative pressure tolerance rating |

5.3003.14 Combustion Analysis of Gas-Fired Appliances (LP and Natural Gas) -

Topic Forced Air
Subtopic System Assessment and Maintenance
Desired Outcome Analysis of critical components and operations completed in accordance with industry and manufacturer specifications

Single-Family Homes, Manufactured Housing

| Title | Specification(s) | Objective(s) |
|-------|------------------|--------------|
|-------|------------------|--------------|

| | | |
|--|---|---|
| | | Ensure equipment: Operates as designed |
| 5.3003.14a Place appliance in operation | Heating equipment will be placed in operation in accordance with applicable NFPA standards and manufacturer specifications when available | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | - |

| | | |
|----------------------------|---|---|
| | | Ensure equipment: Operates as designed |
| 5.3003.14b Gas pressure | Measurement will be verified by a certified professional in accordance with fuel type and manufacturer specifications | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | - |

| | | |
|--|--|----------------------|
| | | Ensure equipment: |
| | | Operates as designed |
| 5.3003.14c Carbon dioxide (CO ₂) and oxygen (O ₂) | Measurement will be verified in accordance with industry manuals (e.g., Testo, Bacharach) | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | - |
| <hr/> | | |
| | | Ensure equipment: |
| | | Operates as designed |
| 5.3003.14d Excess combustion air | Excess combustion air will be calculated and verified in accordance with industry manuals (e.g., Testo, Bacharach) | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | - |
| <hr/> | | |
| | | Ensure equipment: |
| | | Operates as designed |
| 5.3003.14e Carbon monoxide (CO) in flue gas | CO in the undiluted flue gas will be less than <u>1400 ppm air free</u> | Operates safely |
| | | Operates efficiently |

| | | |
|---|---|----------------------|
| | | Is durable |
| | | - |
| | | Ensure equipment: |
| | | Operates as designed |
| 5.3003.14f Testing/inspection holes | All testing and inspection holes will be sealed with manufacturer approved materials | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | - |

| 5.3003.15 Combustion Analysis of Oil-Fired Appliances - | | |
|---|--|---|
| Topic | Forced Air | |
| Subtopic | System Assessment and Maintenance | |
| Desired Outcome | Analysis of critical components and operations completed to industry and manufacturer specifications | |
| Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |
| | Smoke test will be conducted before any combustion testing is completed | Ensure equipment: |
| 5.3003.15a Oil system: smoke test | Smoke spot reading will be in accordance with burner manufacturer specifications | Operates as designed Operates safely Operates efficiently Is durable |
| | - | - |
| | | Ensure equipment: |
| 5.3003.15b Oil system: nozzle | Nozzle size, angle, and spray pattern will be correct for design input and within equipment firing rate of the heating system manufacturer | Operates as designed Operates safely Operates efficiently Is durable |
| | | - |
| | | Ensure equipment: |
| 5.3003.15c Oil filter | Filter will be present, clean, and leak free | Operates as designed Operates safely Operates efficiently Is durable |
| | | - |
| | | Ensure equipment: |
| 5.3003.15d Fuel pressure | Measurement will be verified in accordance with manufacturer specifications | Operates as designed Operates safely Operates efficiently Is durable |
| | | - |
| | | Ensure equipment: |
| 5.3003.15e Oil system: steady state efficiency | Measurement will be verified in accordance with manufacturer specifications | Operates as designed |

| | | | |
|--|---|---|---|
| (SSE) | | Operates safely Operates efficiently Is durable | - |
| | | Ensure equipment: | |
| 5.3003.15f Net stack temperature | Net stack temperature will be measured and verified in accordance with manufacturer specifications | Operates as designed Operates safely Operates efficiently Is durable | - |
| | | Ensure equipment: | |
| 5.3003.15g Carbon dioxide (CO2) and oxygen (O2) | Measurement will be verified in accordance with industry manuals (e.g., Testo, Bacharach) | Operates as designed Operates safely Operates efficiently Is durable | - |
| | | Ensure equipment: | |
| 5.3003.15h Excess combustion air | Excess combustion air will be calculated and shown to be in accordance with industry manuals (e.g., Testo, Bacharach) | Operates as designed Operates safely Operates efficiently Is durable | - |
| | | Ensure equipment: | |
| 5.3003.15i CO in flue gas | CO in the undiluted flue gas will be less than <u>1400 ppm air free</u> | Operates as designed Operates safely Operates efficiently Is durable | - |
| | | Ensure equipment: | |
| 5.3003.15j Testing/inspection holes | All testing and inspection holes will be sealed with approved materials | Operates as designed Operates safely Operates efficiently Is durable | - |

| 2.0100.1 | | Global Worker Safety | |
|-------------------------------------|--|--|--|
| Topic | Safe Work Practices | | |
| Subtopic | Safe Work Practices | | |
| Desired Outcome | Work completed safely without injury or hazardous exposure | | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 2.0100.1a Prevention through design | Design will be incorporated to eliminate or minimize hazards (e.g., material selection, access to equipment for installation and maintenance, placement of equipment, ductwork and condensate lines) | Prevent worker injuries | |
| | | Reduce risk exposure to toxic substances and physical hazards | |
| 2.0100.1b Hand protection | Durable and wrist-protecting gloves will be worn that can withstand work activity | Minimize skin contact with contaminants | |
| | | Protect hands from sharp objects hazards | |
| 2.0100.1c Respiratory protection | If the risk of airborne contaminants cannot be prevented, proper respiratory protection will be provided and worn (e.g., N-95 or equivalent face mask) | Minimize exposure to airborne contaminants (e.g., insulation materials, mold spores, feces, bacteria, chemicals) | |
| | When applying low pressure 2-component spray polyurethane foam, air purifying masks with an organic vapor cartridge and P-100 particulate filter will be used | | |
| | When applying high-pressure SPF insulation, supplied air respirators (SARs) will be used | | |
| | Consult MSDSs for respiratory protection requirements | | |
| | | | |
| 2.0100.1d Electrical safety | An electrical safety assessment will be performed | Avoid electrical shock and arc flash hazards | |
| | | | |

| | | |
|--|--|---|
| | All electric tools will be protected by ground-fault circuit interrupters (GFCI) | |
| | Three-wire type extension cords will be used with portable electric tools | |
| | Worn or frayed electrical cords will not be used | |
| | Water sources (e.g., condensate pans) and electrical sources will be kept separate | |
| | Metal ladders will be avoided | |
| | Special precautions will be taken if knob and tube wiring is present | |
| | Aluminum foil products will be kept away from live wires | |
| | For arc flash hazards, NFPA 70E will be consulted | |
| 2.0100.1e Carbon monoxide (CO) | All homes will have a carbon monoxide alarm | Protect worker and occupant health |
| | Ambient CO will be monitored during combustion testing and testing will be discontinued if ambient CO level inside the home or work space exceeds 35 parts per million (ppm) | |
| 2.0100.1f Protective clothing | MSDSs and OSHA regulations will be consulted for protective clothing and equipment | Protect worker from skin contact with contaminants |
| | Eye protection will always be worn (e.g., safety glasses, goggles if not using full-face respirator) | Minimize spread of contaminants |
| 2.0100.1g Confined space safety | Access and egress points will be located before beginning work | Prevent build-up of toxic or flammable contaminants |
| | Inspection will be conducted for frayed electrical wires | Provide adequate access and egress points |
| | Adequate ventilation will be provided | Prevent electrical shock |
| | Use of toxic material will be reduced | |
| 2.0100.1h Power tool safety | Power tools will be inspected and used in accordance with manufacturer specifications and OSHA regulations to eliminate hazards such as those associated with missing ground prongs, ungrounded circuits, misuse of power tools, noise, and improper or defective cords or extension cords | Prevent power tool injuries |

| | | |
|--|---|--|
| | All devices used will be verified as GFCI protected or double insulated | |
| | Exhaust gases from compressors and generators will be prevented from entering interior space | |
| 2.0100.1i Chemical safety | Hazardous materials will be handled in accordance with manufacturer specifications or MSDS standards to eliminate hazards associated with volatile organic compounds (VOCs), sealants, insulation, contaminated drywall, dust, foams, asbestos, lead, mercury, and fibers | Prevent worker exposure to toxic substances |
| | Appropriate personal protective equipment (PPE) will be provided | |
| | Workers will be trained on how to use PPE | |
| | Workers will be expected to always use appropriate PPE during work | |
| 2.0100.1j Ergonomic safety | Appropriate PPE will be used (e.g., knee pads, bump caps, additional padding) | Prevent injuries from awkward postures, repetitive motions, and improper lifting |
| | Proper equipment will be used for work | |
| | Proper lifting techniques will be used | |
| 2.0100.1k Hand tool safety | Hand tools will be used for intended purpose | Prevent hand tool injuries |
| 2.0100.1l Slips, trips, and falls | Caution will be used around power cords, hoses, tarps, and plastic sheeting | Prevent injuries due to slips, trips, and falls |
| | Precautions will be taken when ladders are used, when working at heights, or when balancing on joists | |
| | Walk boards will be used when practical | |
| | Appropriate footwear and clothing will be worn | |
| 2.0100.1m Heat and thermal stress | Appropriate ventilation, hydration, rest breaks, and cooling equipment will be provided | Prevent heat stroke, heat stress, and cold stress related injuries |
| | 911 will be dialed when necessary | |
| 2.0100.1n Fire safety | Ignition sources will be identified and eliminated (e.g., turn off pilot lights and fuel supply) | Prevent a fire hazard |
| | Use of flammable material will be reduced and fire-rated materials will be used | |

| | | |
|---|---|--|
| <p>2.0100.1o Asbestos-containing materials (ACM)</p> | <p>Assess potential asbestos hazard; if unsure whether material contains asbestos, contact a qualified asbestos professional to assess the material and to sample and test as needed</p> | <p>Protect workers and occupants from potential asbestos hazards</p> |
| | <p>If suspected ACM is in good condition, do not disturb</p> | |
| | <p>If suspected ACM is damaged (e.g., unraveling, frayed, breaking apart), immediately isolate the area(s)</p> | |
| | <p>For suspected ACM that is damaged or that must be disturbed as part of the retrofit activity, contact an asbestos professional for abatement or repair in accordance with federal, state, and local requirements; only a licensed or trained professional may abate, repair, or remove ACM</p> | |
| | <p>When working around ACM, do not:</p> | |
| | <p>Dust, sweep, or vacuum ACM debris</p> | |
| | <p>Saw, sand, scrape, or drill holes in the material</p> | |
| | <p>Use abrasive pads or brushes to strip materials</p> | |
| | <p>Asbestos abatement or repair work should be completed prior to blower door testing; exercise appropriate caution when conducting blower door testing where friable asbestos or vermiculite attic insulation is present to avoid drawing asbestos fibers into the living space (i.e., use positively pressurized blower door testing) unless the material has been tested and found not to contain asbestos</p> | |
| | <p>2.0100.1p Lead paint assessment</p> | |
| <p>The Environmental Protection Agency (EPA) Renovation, Repair, and Painting (RRP) Program Rule (40 CFR Part 745) in pre-1978 homes and proposed changes to this rule (Federal Register/Vol. 75, No. 87/May 6, 2010) will be complied with, to be superseded by any subsequent final rulemaking or any more stringent state or federal standards</p> | | |

| 2.0401.1 | | Air Sealing Moisture Precautions | |
|--|---|---|--|
| Topic | Moisture | | |
| Subtopic | Air Sealing | | |
| Desired Outcome | Ensure durability of repairs and reduce potential for occupant exposure to mold and other moisture-related hazards | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 2.0401.1a Moisture precautions for attics Comment | Roof leaks will be repaired before performing attic air sealing or insulation | Ensure durability of repairs | |
| | Moisture sources in the house that can generate moisture into the attic will be identified and removed or reduced | Reduce potential for occupant exposure to mold and other moisture-related hazards | |
| | | Prevent moisture from communicating from within the conditioned space into unconditioned attic space when economically feasible | |
| 2.0401.1b Moisture precautions for crawl spaces Comment | Exposed earth will be covered with a continuous, durable, sealed Class 1 vapor retarder a minimum of 6 mils in thickness | Ensure durability of repairs | |
| | Plastic, foil or any other Class 1 vapor barrier/retarder will not be used in hot humid climates | Reduce potential for occupant exposure to mold and other moisture-related hazards | |
| | <u>Any vapor retarder shall not encapsulate wood building materials or spray foam</u> | | |
| | All accessible penetrations between the crawl space or basement and outside will be sealed | | |
| | Holes between the crawl space or basement and the living space will be sealed | | |
| 2.0401.1c Moisture precautions for the living space Comment | Moisture sources in the home will be identified and removed or reduced | Ensure durability of repairs | |
| | Local ventilation will be installed where appropriate (e.g., baths, kitchens) and vented to outside according to ASHRAE 62.2-2010 | Reduce potential for occupant exposure to mold and other moisture-related hazards | |
| | | | |

| | | |
|--|---|---|
| | Unvented combustion appliances that are not listed to ANSI Z21.11.2 will be removed | |
| 2.0401.1d Moisture precautions for exterior water Comment | Before air sealing basement or crawl space walls near wet areas, surface water pooling near the foundation will be addressed by: | Reduce potential for occupant exposure to mold and other moisture-related hazards |
| | Repairing, modifying or replacing gutters and downspouts | |
| | Grading and subsurface drainage at critical locations (e.g., localized drain and grading beneath valleys) in accordance with Environmental Protection Agency (EPA) Indoor airPLUS Construction Specifications Section 1.1 | |
| | Possible mitigation by waterproofing or installing draining plane with construction adhesive | |

Manufactured Housing

| Title | Specification(s) | Objective(s) |
|--|---|---|
| 2.0401.1a Moisture precautions for attics Comment | Roof leaks will be repaired before performing attic air sealing or insulation | Ensure durability of repairs |
| | Moisture sources in the house that can generate moisture into the attic will be identified and removed or reduced | Reduce potential for occupant exposure to mold and other moisture-related hazards |
| | Water-resistant sealants and/or closed cell foams (use a minimum of 2" to reach water barrier requirement) will be used in all attic sealing details in cold climates | Prevent moisture from communicating from within the conditioned space into unconditioned attic space when economically feasible |
| | Plastic, foil, or any other Class 1 vapor barrier will not be used in hot humid climates | Increase durability of seal |
| | In marine climates, vapor permeable materials will be used to block and seal penetrations in attic | Avoid moisture-related damage to the home |
| | | |

| | | |
|--|---|---|
| | | |
| 2.0401.1b Moisture precautions for crawl spaces Comment | Exposed earth will be covered with a continuous, durable, sealed Class 1 vapor retarder a minimum of 6 mils in thickness | Ensure durability of repairs |
| | Plastic, foil, or any other Class 1 vapor barrier/retarder will not be used in hot humid climates <u>Any vapor retarder shall not encapsulate wood building materials or spray foam</u> | Reduce potential for occupant exposure to mold and other moisture-related hazards |
| | All accessible penetrations between the crawl space or basement and outside will be sealed | |
| | Holes between the crawl space or basement and the living space will be sealed | |
| 2.0401.1c Moisture precautions for the living space Comment | Moisture sources in the home will be identified and removed or reduced | Ensure durability of repairs |
| | Local ventilation will be installed where appropriate (e.g., baths, kitchens) and vented to outside according to ASHRAE 62.2-2010 | Reduce potential for occupant exposure to mold and other moisture-related hazards |
| | Unvented combustion appliances that are not listed to ANSI Z21.11.2 will be removed | |
| 2.0401.1d Moisture precautions for exterior water Comment | Before air sealing basement or crawl space walls near wet areas, surface water pooling near the foundation will be addressed by: | Reduce potential for occupant exposure to mold and other moisture-related hazards |
| | Repairing, modifying, or replacing gutters and downspouts | |
| | Grading and subsurface drainage at critical locations (e.g., localized drain and grading beneath valleys) in accordance with EPA) Indoor airPLUS Construction Specifications Section 1.1 | |
| | Possible mitigation by waterproofing or installing draining plane with construction adhesive | |

| | | |
|---|---|--|
| 2.0403.1 | Vented Crawl Spaces—Ground Moisture Barrier | |
| Topic | Moisture | |
| Subtopic | Vapor Barriers | |
| Desired Outcome | Durable, effective ground moisture barrier provides long-lasting access and minimizes ground vapor | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 2.0403.1a Material Integrity | Care will be taken to prevent punctures during installation | Protect ground moisture barrier from damage during other crawl space work |
| 2.0403.1b Coverage | A ground moisture barrier that covers 100% of the exposed crawl space floor will be installed | Reduce ground moisture entering the crawl space |
| 2.0403.1c Material specification | A ground moisture barrier with a rating of no more than 0.1 perm will be used | Ensure crawl space is accessible for service and maintenance without damaging the integrity of the ground moisture barrier |
| | A ground moisture barrier will be used that meets tear and puncture resistance standard ASTM E1745 | |
| | Homeowner will be advised that all plastic is biodegradable and will have a life span much shorter than the home (5 years), and it will need replacing to remain effective | |
| 2.0403.1d Overlap seams | When seams exist, they will be overlapped a minimum of 12" using reverse or upslope lapping technique | Keep water under the liner |
| | | Reduce the likelihood of damage at seams |
| 2.0403.1e Fastening | <u>When Gground moisture barrier is installed on sloping ground, may be exposed to wind, or accessed for routine maintenance or storage it</u> will be fastened to ground with durable fasteners or ballast(s) and extend a minimum of 6" up the foundation wall | Prevent movement of the ground moisture barrier |

| 2.0403.2 | | Closed Crawl Spaces—Ground Moisture Barriers | |
|---|--|---|--|
| Topic | Moisture | | |
| Subtopic | Vapor Barriers | | |
| Desired Outcome | Durable, effective air barrier and ground moisture barrier provide ongoing access and minimize ground vapor | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 2.0403.2a Material Integrity | Care will be taken to prevent punctures during installation | Protect ground moisture barrier from damage during other crawl space work | |
| 2.0403.2b Coverage | An air barrier and ground moisture barrier, covering 100% of the exposed crawl space floor, will be installed and sealed to the wall's air and moisture barrier in accordance with ASTM E1643 and manufacturer's recommendations | Reduce ground moisture entering the crawl space | |
| | Ground moisture barrier will be fastened to ground in accordance with manufacturer's recommendations and extend a minimum of 6 inches up the foundation wall | Create a continuous and durable connection between the wall and ground air and moisture barriers | |
| 2.0403.2c Material specification | A ground moisture barrier with a rating of no more than 0.1 perm will be used | Reduce ground vapor entering the crawl space | |
| | A ground moisture barrier will be used that meets tear and puncture resistance standard ASTM E1745 | Ensure crawl space is accessible for service and maintenance without destroying the integrity of the moisture barrier | |
| | Homeowner will be advised that all plastic is biodegradable and will have a life span much shorter than the home (5 years), and it will need replacing to remain effective | | |
| 2.0403.2d Overlap seams | When seams exist, they will be overlapped a minimum of 12" with reverse or upslope lapping technique | Keep water under the liner | |
| | For wall to floor connection, the wall moisture barrier will be installed under the ground moisture barrier | | |

| | | |
|---|--|--|
| 2.0403.2e Fastening | The air barrier and When ground moisture barrier is installed on sloping ground, or accessed for routine maintenance or storage it will be fastened to the ground with durable fasteners or ballast(s) to prevent movement in accordance with ASTM E1643 and manufacturer's recommendations | Prevent movement and uplift of the air barrier and ground moisture barrier |
| 2.0403.2f Sealing seams | A durable sealant compatible with the air barrier and ground moisture barrier will be used | Maintain continuous air barrier and ground moisture barrier |
| 2.0403.2g Air barrier, ground moisture barrier penetrations, including fastener penetrations | A durable sealant, compatible with the air barrier and ground moisture barrier, will be used | Maintain continuous air barrier and ground moisture barrier |
| | Physical attachments will be provided where practical (e.g., masonry columns, footings) | |
| 2.0403.2h Drainage | The air barrier and ground moisture barrier will not interfere with the established drainage pattern | Ensure proper drainage |
| 2.0403.2i Drainage points | Interior drainage collection points will be accessible from above and below the air barrier and ground moisture barrier | Remove water above and below the air barrier and ground moisture barrier |

| 2.0601.1 | | Knob and Tube Wiring | |
|---|---|--|--|
| Topic | Electrical | | |
| Subtopic | Knob and Tube Wiring | | |
| Desired Outcome | Live unsafe wiring identified and brought to local codes | | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 2.0601.1a Knob and tube identification | Contractor, assessor, auditor, or similar will inspect and assess the house to identify knob and tube wiring | Ensure occupant safety | |
| | | Preserve the integrity and safety of the house | |
| 2.0601.1b Live wire testing | Non-contact testing method will be used to determine if wiring is live | Protect occupant safety | |
| | | Preserve the integrity and safety of the house | |
| 2.0601.1c Isolation and protection | <u>Proper clearance will be maintained around</u> live knob and tube will not be covered or surrounded; <u>as</u> required by the National Electrical Code (NEC) or authority having jurisdiction | Ensure occupant safety | |
| | A licensed electrical contractor will inspect and certify wiring to be safe and place a warning at all entries to the attic about the presence of knob and tube wiring | Preserve the integrity and safety of the house | |
| | <u>When required, a</u> dam that does not cover the top will be created to separate insulation from the wire path | | |
| | | | |
| 2.0601.1d Replacement | Exposed wiring will be replaced with new appropriate wiring in accordance with the NEC and local codes | Ensure occupant safety | |
| | Old wiring will be rendered inoperable by licensed electrician in accordance with the NEC and local codes | Preserve the integrity and safety of the house | |

| 2.0702.1 | | Warranty and Service Agreement | |
|--|---|--|--|
| Topic | Occupant Education and Access | | |
| Subtopic | Installed Equipment | | |
| Desired Outcome | Occupants provided recourse for failures in materials, workmanship, and serviceability and informed of potential hazards | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 2.0702.1a Warranty | A minimum 1-year warranty for materials, workmanship, and serviceability will be provided to occupants upon completion of work | Provide recourse to occupants for failures in materials, workmanship, and serviceability | |
| 2.0702.1b Warranty renewal and service <u>Maintenance agreement Agreement – Client Education</u> | <p><u>Provide occupants with manufacturers' warranties on installed equipment and inform of installer maintenance agreement options</u></p> <p><u>Share information on company related annual inspections and maintenance agreements as well as manufacturer related warranty details</u>An option for annual inspection and renewal of warranty and service agreement for up to 10 years will be offered at a cost (requirement for installers)</p> | <p><u>Ensure occupants are aware of warranty and maintenance agreement options</u>Provide occupants with an option for extending the warranty and service agreement</p> | |
| 2.0702.1c General conditions | <p>At a minimum, the following concerns and warnings will be addressed within the warranty:</p> <p>Possible drying and shrinking effects</p> <p>Storage of hazardous and flammable materials</p> <p>Mold</p> | Educate occupants on potential hazards | |

| 3.1201.1 | Double-Hung Wood Windows | |
|--|---|--|
| Topic | Windows and Doors | |
| Subtopic | Maintenance, Repair, and Sealing | |
| Desired Outcome | Windows operable and weather tight; improved energy efficiency performance of fenestration | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 3.1201.1a Lead paint assessment | Presence of lead-based paint in pre-1978 homes will be assumed unless testing confirms otherwise | Protect worker and occupant from potential lead hazards |
| | EPA's Renovation, Repair and Painting (RRP) Program Rule (40 CFR Part 745) in pre-1978 homes and proposed changes to this rule (Federal Register/Vol. 75, No. 87/May 6, 2010) will be complied with, to be superseded by any subsequent final rulemaking or any more stringent state or federal standards | |
| 3.1201.1b Weather stripping | Existing weather stripping and sash sealant will be removed | Form a complete seal from the outer edge of the sash to the jamb |
| | Surface where the sill meets the sash will be cleaned | Maintain operability of the window |
| | Seal between the fixed components of the window (e.g., jambs, sill) will be continuous and complete while maintaining the operability of the window | |
| | Continuous and complete weather stripping will be installed on the bottom of the lower sash where it makes contact with the sill and at the top of the upper sash where it makes contact with the upper part of the window frame | |
| | | |
| 3.1201.1c Sash locks | Locks will be installed so that the rails of the upper and lower sashes are flush and in full contact | Form a secure connection between the two sashes |
| | No gaps will be visible between the two sashes | |
| | Locks will be installed to achieve compression of the two sashes | |

| | | |
|------------------------------------|---|--|
| 3.1201.1d Replacement sills | Beveled sill will be flush with interior wall and sloped to the exterior | Form a complete seal from the bottom of the lower sash to the sill |
| | Seams will be continuously and completely sealed with sealant to the jambs and to the frame | Maintain operability of the window |
| | Sill will be water-sealed and primed | Allow for drainage to the exterior |
| 3.1201.1e Sash replacement | Lower sash will have the same bevel on the bottom rail as the sill | Ensure sash remains in a fixed position when open or partially open |
| | Sash will be water-sealed and primed | Maintain operability of the window |
| | | Form a complete seal from the bottom of the lower sash to the sill |
| 3.1201.1f Adjust stops | Stops will be adjusted to eliminate visible gaps between the stops and the jamb while maintaining operability of the window | Form a complete seal between the jamb, sash, and stop |
| | | Maintain operability of the window |
| 3.1201.1g Replace stops | Stops will be installed to keep the window securely in place | Form a complete seal between the jamb, sash, and stop |
| | Stops will be adjusted to eliminate visible gaps between the stops and the jamb while maintaining operability of the window | Maintain operability of the window |

| 3.1601.8 | | |
|--|--|---|
| Preparation and Mechanical Fastening— Mid and High Rise | | |
| Topic | Ducts | |
| Subtopic | Duct Preparation | |
| Desired Outcome | Ducts and plenums properly fastened to prevent leakage | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 3.1601.8a Preparation | Surrounding insulation will be cleared to expose the joints being sealed | Gain access |
| | Duct surface that accepts sealant will be cleaned | Achieve proper adhesion for airtight seal |
| 3.1601.8b Metal to metal | Ducts will be fastened with a minimum of three equally spaced screws or acceptable mechanical connections | Ensure joints are durable |
| | | Reduce air leakage |
| 3.1601.8c Flex to metal (150) | Joints will be fastened with tie bands using a tie band tensioning tool or mechanical band, and sealed with approved mastic and UL181B tape. Must have a minimum performance temperature rating of 165° (per UL 181A-type test) and a minimum tensile strength rating of 50 pounds | Ensure joints are durable |
| | | Reduce air leakage |
| 3.1601.8d Duct board to duct board | In a repair or replacement, joints will be fastened with clinch stapler, rated tape, and mastic | Ensure joints are durable |
| | | Reduce air leakage |
| 3.1601.8e Duct board to flexible duct (152) | An approved take-off collar in accordance with NAIMA standards will be used and sealed with approved mastic | Ensure joints are durable |
| | | Reduce air leakage |
| 3.1601.8f Phenolic board to phenolic board | Joints will be a metal connection fastened together in accordance with manufacturer specifications | Ensure joints are durable |
| 3.1601.8g Phenolic board to flexible duct | Metal take-off collar will be used and mastic will be used on the outside in accordance with manufacturer specifications | Ensure joints are durable |
| | | Reduce air leakage |
| 3.1601.8h Phenolic board to air handler cabinet | Plenum will be fastened with a minimum of three equally spaced screws on each side and sealed with mastic | Ensure joints are durable |
| | Canvas connection between plenum and unit will be installed so that it does not reduce the inside diameter of the duct | Optimize air flow |
| | | Reduce air leakage |

| | | |
|---|--|--------------------------------------|
| 3.1601.8i Metal plenum to air handler cabinet | Plenum will be fastened with a minimum of three equally spaced screws on each side and sealed with mastic | Ensure joints are durable |
| | Canvas connection between plenum and unit will be installed so that it does not reduce the inside dimensions of the duct | Optimize air flow |
| | | Reduce air leakage |
| | | |
| 3.1601.8j Duct board plenum to air handler cabinet | Termination bar or metal strip will be fastened with screws and sealed with mastic | Ensure joints are durable |
| | Duct board will be installed between the screw and the termination bar | Reduce air leakage |
| 3.1601.8k Terminal boot to wood | Screws or nails will be used to fasten boot to wood | Ensure joints are durable |
| | Seams and boot to subfloor will be sealed with mastic | Reduce air leakage |
| 3.1601.8l Terminal boot to gypsum | Boot hanger will be fastened to adjacent framing with screws or nails | Ensure joints are durable |
| | Boot will be connected to boot hanger with screws | Reduce air leakage |
| | Integral snap boots will be installed | |
| | Seams of the boot will be sealed with mastic | |
| | Boot to gypsum will be sealed with caulk in accordance with local code and standards | |
| | | |
| 3.1601.8m Replacement of insulation | Insulation will be returned or replaced with current insulation standards | Insulation values will be maintained |

| | | |
|---|---|--|
| 3.1802.1 | Roof/Exterior Wall Connection, Including Joints at Roof/Parapet/Wall Connections | |
| Topic | Roofs | |
| Subtopic | Roof/Wall Connections | |
| Desired Outcome | Continuous air barrier between roof and exterior walls where connection is within conditioned space | |
| Single-Family Homes, Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 3.1802.1a Pre-inspection | Conduct pre-inspection in accordance with SWS 2.0100.4 Work Area Inspection and Stabilization | Provide a safe and stable work environment |
| | Existing water control measures will be identified | Avoid compromising existing water control system |
| | Air sealing locations will be identified between the roof and the exterior wall | Ensure a continuous air barrier will be appropriately located at the roof/exterior wall junction |
| 3.1802.1b Backing and infill | Where gaps, cracks, or holes are larger than 1/4" across and/or where the air sealing materials will be subject to temperature variations in excess of 50° F, the need for backing or infill will be evaluated | Minimize gap or hole size to ensure successful use of sealant |
| | If used, backing or infill will meet specific characteristics of the fire-resistance-rated assembly, and be compatible with the characteristics of the gap, crack, or hole, including preservation of any expansion/contraction characteristics for assembly (e.g., expansion joints, steam pipes, or dissimilar material interfaces with differing coefficients of expansion) | Ensure closure is permanent and supports appropriate load (e.g., wind, snow, insulation) |
| | Backing or infill will be selected that maintains sealant placement and durability while allowing for the expected movement from expansion, contraction, load deflection, settling at the location, or if existing water control measures are compromised (e.g., rain screen, drip edge, weep holes, gutter and roof drains, scuppers, or other exterior water management elements) | Ensure sealant does not fall out |
| | | Ensure integrity of the existing water control system |

| | | |
|------------------------------------|--|--|
| 3.1802.1c Sealant selection | Sealants will be compatible with their intended surfaces and applied in accordance with manufacturer specifications | Prevent intrusion of moisture and pests into the sealed assembly |
| | | |
| | Selection will be durable, pest resistant, and have a weather-appropriate seal | Prevent exposing workers or occupants to excessive VOC levels |
| | | |
| | Indoor sealants will be low volatile organic compound (VOC) products that meet independent testing and verification protocols, such as Green Seal GS-36, "GREENGUARD Children and Schools," or comparable certifications | Ensure sealant meets or exceeds the performance characteristics of the assembly and is compliant with local fire code requirements |
| | | |
| | Fire-resistance-rated assemblies will be provided with sealants permitted by the authority having jurisdiction and adopted building code | |
| 3.1802.1d Joint seal | Continuous seal will be installed at roof/exterior wall junctions or roof/exterior and wall/parapet junctions, including, but not limited to, beams, cracks, joints, edges, penetrations, and connections | Provide airtight, durable seal that does not move, bend, or sag |
| | | |
| | For metal roof decks, flutes will be accessed to install sealant between top side of roof deck and roof assembly | Ensure hidden flutes are properly sealed |
| 3.1802.1e Cavity seal | For framed parapets that are open between conditioned and unconditioned space, the parapet/wall cavity will be accessed, and an internal air barrier will be created within the parapet wall cavity at the roof plane | Stop air movement within the parapet/wall cavity to create a continuous air barrier at the roof plane |
| | | |
| | For parapet walls constructed with hollow core concrete masonry units, the hollow cores will be accessed at the roof plane, and an internal air barrier will be created within the parapet wall cavity at the roof plane | Provide airtight, durable seal that does not move, bend, or sag |
| | | |
| | For exterior insulated finishing system (EIFS) parapet, air sealing measures will preserve designed moisture control gaps between EIFS and wall sheathing | |

| 4.1001.1 | | |
|---|---|--|
| Non-Insulation Contact (IC) Recessed Light | | |
| Topic | Attics | |
| Subtopic | General Preparation | |
| Desired Outcome | Ensure safety from fire and prevent air leakage | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1001.1a Air barrier system | A fire-rated air barrier system (i.e., equivalent to 5/8 fire code gypsum wallboard) will be used to separate non-IC rated recessed lights from insulation, using one of the methods below: | Prevent a fire hazard |
| | A fire-rated airtight closure taller than surrounding attic insulation will be placed over non-IC rated recessed lights | Prevent air leakage through fixture |
| | OR | |
| | The non-IC rated light fixture will be replaced with an airtight and IC- rated fixture | |
| | OR | |
| | The fixture(s) may be replaced with surface mounted fixture and opening sealed | |
| | OR | |
| | Air sealing measures as approved by the authority having jurisdiction | |
| | | |
| 4.1001.1b Enclosure top | The top-fire rated enclosure material will have an R-value of 0.56 or less | Prevent heat build up |
| | The top of the enclosure will be left free of insulation | |
| 4.1001.1c Clearance | The entire closure will maintain a 3" clearance between the closure and the fixture including wiring, box, and ballast | Keep an air space around the fixture |
| 4.1001.1d Sealants and weather stripping | Caulk, mastic, or foam will be used on all edges, gaps, cracks, holes, and penetrations of closure material only | To prevent air leakage, completely adhere the sealant to all surfaces to be sealed |

| 4.1001.3 Fireplace Chimney and Combustion Flue Vents | | |
|--|---|---|
| Topic | Attics | |
| Subtopic | General Preparation | |
| Desired Outcome | Combustible materials kept away from combustion sources | |
| Single-Family Homes, <u>Manufactured Housing</u> | | |
| Title | Specification(s) | Objective(s) |
| 4.1001.3a Verify attic prep | Holes, penetrations, and bypasses will be sealed | Prevent air leakage |
| | Dams will be fixed in places that maintain required clearance | Ensure insulation dams maintain clearance |
| 4.1001.3b Required clearance | A rigid dam having a height greater than the insulation to be installed will be constructed to ensure a 3" clearance <u>area free of insulation or combustibles</u> between combustion flue vent and dam, <u>unless the flue vent is listed for a lesser clearance</u> | Ensure dam material does not bend, move, or sag |
| | Chimney vents will have an airspace clearance to combustibles in accordance with 2012 IRC M1801.3.4 | Prevent a fire hazard |
| 4.1001.3c Safety | Insulation will not be allowed between a heat-generating appliance and a dam unless material is rated for contact with heat generating sources | Prevent a fire hazard |
| 4.1001.3d Occupant education | Documentation of material and R-value will be provided to occupant | Provide occupant with documentation of installation |

| 4.1003.1 | | |
|--|--|--|
| Pitched/Vaulted/Cathedralized Ceilings— Loose Fill Over | | |
| Topic | Attics | |
| Subtopic | Attic Ceilings | |
| Desired Outcome | Reduce the rate of heat transfer through cathedral or vaulted ceiling | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1003.1a Ventilation | Venting will be continuous, if applicable | Ensure capacity to increase R-value while not altering ventilation |
| 4.1003.1b Lighting | Existence of rated insulation contact can lights, which allow for insulation encapsulation, will be verified | Prevent a fire hazard |
| | Non-insulation contact rated can lights will not be insulated | |
| 4.1003.1c Installation | When using cellulose, stabilized product is preferred when available | Ensure appropriate material and application |
| | On roof pitches less than 6/12, loose fill cellulose can be used; on roof pitches greater than 6/12, install Insulweb non-woven polypropylene netting (webbing) baffles of the same height as the insulation every 6' across slope to prevent the loose fill insulation from sliding downward, or dense pack cellulose above Insulweb webbing stapled to the bottom (underside) of the rafters | Insulate to prescribed R-value |
| | Loose fill fiberglass will only be used on a slope less than or equal to a 6/12 pitch or the slope application approved by the manufacturer, whichever is less (dense packed fiberglass at slopes greater than 6/12 may be used) | |
| | Roof cavities will be insulated with loose fill according to manufacturer specifications without gaps, voids, compressions, misalignments, or wind intrusions | |
| | Insulation will be installed to prescribed R-value | |
| | | |

| | | |
|---|---|--|
| 4.1003.1d Occupant education | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | | |
| | Insulation type | Confirm amount of insulation installed |
| | | |
| | Coverage area | Ensure ability to match bags required for total area completed |
| | | |
| | R-value | Comply with 16 CFR 460.17 |
| | | |
| | Installed thickness and minimum settled thickness | |
| | | |
| Number of bags installed in accordance with manufacturer specifications | | |

| | | |
|---------------------------------------|--|--|
| 4.1003.2 | Pitched/Vaulted/Cathedralized Ceilings— Dense Pack Over | |
| Topic | Attics | |
| Subtopic | Attic Ceilings | |
| Desired Outcome | Insulation reduces heat transfer through ceiling and closed attic sections as well as framing cavities inaccessible to other treatments | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1003.2a Fill slant ceilings | Using fill tube, 100% of each cavity will be filled to a consistent density: | Ensure complete and consistent coverage throughout ceiling plane |
| | Cellulose material will be installed to a minimum density of 3.5 pounds per cubic foot | Eliminate voids and settling |
| | Loose fiberglass material will be installed and will be specifically approved for air flow resistance per manufacturer's recommendations | |
| | | Minimize framing cavity air flows |
| | The number of bags installed will be confirmed and will match the number required on the coverage chart | |
| | | |
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference <u>using chemical smoke, IR scans, or other approved verification method.</u> | |
| 4.1003.2b Onsite documentation | A dated receipt signed by the installer will be provided that includes:• Coverage area• Thickness• R-value | Document job completion to contract specifications |
| | | Confirm amount of insulation installed |
| | | Comply with 16 CFR 460.17 |

| 4.1004.2 | | Preparation for Batt Insulation | |
|------------------------------------|--|--|--|
| Topic | Attics | | |
| Subtopic | Knee Walls | | |
| Desired Outcome | Airtight cavity and properly insulated knee wall | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 4.1004.2a Knee wall prep for batts | All knee walls will have a top and bottom plate or blockers installed using a rigid material | Eliminate bending, sagging, or movement that may result in air leakage | |
| | All joints, cracks, and penetrations will be sealed in finished material, including interior surface to framing connections | Prevent air leakage through the top or bottom of the knee wall | |
| | <u>When knee wall floor and walls are being insulated, the floor joist running under the knee wall will be air sealed.</u> | Create an air barrier | |
| 4.1004.2b Installation | Insulation will be installed using one of the following methods: | Eliminate misalignment of existing insulation | |
| | New batts will be installed in accordance with manufacture specifications | | |
| | All existing batted insulation will be adjusted to ensure it is in full contact with the interior cladding and the top and bottom plates | | |
| 4.1004.2c Backing knee wall | If rigid material is used, material will be installed to cover 100% of the surface of the knee wall | Prevent insulation from settling or moving | |
| | If foam sheathing is used, sheathing will be listed for uncovered use in attic, or covered with a fire barrier | | |

| 4.1005.2 | | Accessible Floors—Loose Fill Installation | |
|--------------------------------|--|--|--------------------------|
| Topic | Attics | | |
| Subtopic | Attic Floors | | |
| Desired Outcome | Consistent, thermal boundary between conditioned and unconditioned space controls the heat flow | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 4.1005.2a Preparation | Subfloor or drywall will be removed to access cavities as necessary, including inaccessible knee-wall attic floor spaces | Access the workspace | |
| | Insulation will be adequately marked for depth a minimum of every 300 square feet of attic area, with measurement beginning at the air barrier | Verify uniformity of insulation material | |
| | All electrical boxes will be flagged to be seen above the level of the insulation | Provide location of electrical boxes for future servicing | |
| | Open electrical junctions will have covers installed | Prevent an electrical hazard | |
| | Insulation dams and enclosures will be installed as required | | |
| | 4.1005.2b Air barrier | Existence of air barrier material in line with the knee walls will be installed or verified when dense packing | Hold dense pack in place |
| | Air barrier material will not bend, sag, or move once dense packed | | |
| 4.1005.2c Installation | All insulation will be installed to the minimum unsettled depth and the maximum coverage per bag to reach a consistent depth indicated on the manufacturer coverage chart for desired R-value indicated on the manufacturer coverage chart indicated on the manufacturer's coverage chart . | Reduce heating and air conditioning costs | |
| | | Improve comfort | |
| | | Minimize noise | |
| 4.1005.2d Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications | |
| | Insulation type | Confirm amount of insulation installed | |
| | Coverage area | | |
| | R-value | Ensure ability to match bags required for total area completed | |
| | Installed thickness and settled thickness | | |

| | | |
|---|---|---|
| | Number of bags installed in accordance with manufacturer specifications | Comply with 16 CFR 460.17 |
| 4.1005.3 | Accessible Floors—Batt Insulation Over Existing Insulation | |
| Topic | Attics | |
| Subtopic | Attic Floors | |
| Desired Outcome | Insulation controls heat transfer through ceiling | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1005.3a Preparation | Existing insulation will be in contact with the air barrier prior to installing additional insulation on top | Ensure proper performance of insulation |
| 4.1005.3b Installation | If the top of the existing insulation is below the top of the framing, new batts will be installed parallel with framing members | Ensure uniform depth of insulation in continuous contact with existing insulation |
| | If the top of the existing insulation is above the top of the framing, new batts will be installed perpendicular to framing members | Eliminate voids and gaps |
| 4.1005.3c Insulation | <u>Batts will be installed in accordance with manufacturer specifications without gaps, voids, compressions, misalignments, or wind intrusions</u> A dated receipt signed by the installer will be provided that includes: | <u>Insulate to prescribed R-value</u> Document job completion to contract specifications |
| | <u>Insulation will be installed to prescribed R-value</u> | |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | Ensure ability to match bags required for total area completed |
| | R-value | Comply with 16 CFR 460.17 |
| 4.1005.3d Safety | Insulation will not be allowed on top of non-IC rated can light boxes or between a heat generating appliance and a dam, unless material is rated for contact with heat generating sources | Prevent a fire hazard |
| 4.1005.3e Occupant Onsite education—documentation | <u>A dated receipt signed by the installer will be provided that includes: Documentation of material and R-value will be provided to occupant</u> | <u>Document job completion to contract specifications</u> Provide occupant with documentation of installation |

| | | |
|--|----------------------|---|
| | <u>Coverage area</u> | <u>Confirm amount of insulation installed</u> |
| | | |
| | <u>Thickness</u> | <u>Ensure ability to match bags required for total area completed</u> |
| | | |
| | <u>R-value</u> | <u>Comply with 16 CFR 460.17</u> |

| 4.1005.6 Enclosed Attic Storage Platform Floor— Dense Pack Installation | | |
|--|---|--|
| Topic | Attics | |
| Subtopic | Attic Floors | |
| Desired Outcome | Insulation reduces heat flow through floor and framing cavities inaccessible to other treatments | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1005.6a Fill floors | Each cavity will be 100% filled to consistent density: | Eliminate voids and settling |
| | Cellulose material will be installed to a minimum density of 3.5 pounds per cubic foot <u>or to a maximum density structurally allowable</u> | Minimize framing cavity air flows |
| | Loose fiberglass material will be installed and will be specifically approved for air flow resistance to a minimum density per the manufacturer's recommendations | |
| | The number of bags installed will be confirmed and will match the number required on the coverage chart | |
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference | |
| | | |
| 4.1005.6b Safety | Insulation will not be allowed on top of non-IC rated can light boxes or between a heat generating appliance and a dam, unless material is rated for contact with heat generating sources | Prevent a fire hazard |
| 4.1005.6c Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | Comply with 16 CFR 460.17 |
| | R-value | |
| | | |

| 4.1005.7 | Attic Floor—Preparation and Installation of Spray Polyurethane Foam (SPF) | |
|--------------------------------|--|---|
| Topic | Attics | |
| Subtopic | Attic Floors | |
| Desired Outcome | Consistent, thermal boundary and air barrier between conditioned and unconditioned space controls the heat flow and air leakage | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1005.7a Preparation | Subfloor or drywall will be removed to access cavities as necessary (e.g., beneath attic knee walls) | Access the workspace |
| | All electrical junctions will be flagged to be seen above the level of the insulation | Provide location of electrical junctions for future servicing |
| | Open electrical junction boxes will have covers installed | Prevent an electrical hazard |
| 4.1005.7b Installation | Insulation will be installed to prescribed R-value | Insulate to prescribed R-value |
| | SPF will be applied to desired thickness onto attic floor to ceiling material below between attic floor joists using pass thickness maximum as indicated by manufacturer | |
| 4.1005.7c Safety | <u>Spray foam should never be installed over light fixtures regardless of if fixture is rated for IC or not.</u> Nor insulation will not be allowed on top of non-IC rated can light boxes or between a heat-generating appliance and a dam, unless material is rated for contact with heat-generating sources | Prevent a fire hazard |
| 4.1005.7d Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | Comply with 16 CFR 460.17 |
| | R-value | |
| 4.1005.7e Occupant education | Documentation of material and R-value will be provided to occupant | Provide occupant with documentation of installation |

| 4.1006.1 | Pull-Down Stairs | |
|--|---|--|
| Topic | Attics | |
| Subtopic | Attic Openings | |
| Desired Outcome | Pull-down attic stair properly sealed and insulated | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1006.1a Installation | Hatches will be insulated to the maximum R-value structurally allowable up to the R-value of the adjoining insulated assembly | Achieve uniform R-value |
| | Pull-down stair rough opening will be surrounded with a durable dam that is higher than the level of the attic floor insulation | Prevent loose insulation from entering the living area |
| | Counter-weights should be considered to ease accessibility for excessively heavy hatches | |
| 4.1006.1b Sealing | Entire pull-down stair assembly will be covered with an airtight and removable/openable enclosure inside the attic space | Prevent air leakage |
| | Pull-down stair frame will be caulked, gasketed, weatherstripped, or otherwise sealed with an air barrier material, suitable film, or solid material that allows attic door operation | |
| 4.1006.1c Durability | Completed measure will meet a minimum expected service life of 20 years | Ensure a minimum expected service life |
| 4.1006.1d Occupant Onsite education documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | Comply with 16 CFR 460.17 |
| | R-value | |

| 4.1006.2 | Access Doors and Hatches | |
|---|--|--|
| Topic | Attics | |
| Subtopic | Attic Openings | |
| Desired Outcome | Attic access door properly sealed and insulated | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1006.2a Installation | Hatches will be insulated to the maximum R-value structurally allowable up to the R-value of the adjoining insulated assembly | Achieve uniform R-value on the attic door or hatch |
| | Attic hatches rough opening will be surrounded with a durable protective baffle that is higher than the level of the surrounding attic floor insulation | Achieve uniform R-value on the attic floor |
| | | Prevent loose attic floor insulation from entering the living area |
| 4.1006.2b Sealing | Access hatch frames will be sealed using caulk, gasket, weather-strip, or otherwise sealed with an air barrier material, suitable film, or solid material | Prevent air leakage |
| | Options will include installing a latch or lock or frictionally engaged components of a pre-fabricated unit above the opening that do not require a latch | |
| | The measure must include a protective baffle or insulation barrier | |
| 4.1006.2c Attachment | Insulation will be permanently attached and in complete contact with the air barrier | Insulate to prescribed R-value |
| 4.1006.2d Durability | Completed measure will meet a minimum expected service life of 20 years | Ensure a minimum expected service life |
| 4.1006.2e Occupant education <u>Onsite documentation</u> | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | Comply with 16 CFR 460.17 |
| | R-value | |
| | | |

| 4.1088.8 | | Installation/Correction of Unconditioned Attic Ventilation | |
|---|---|--|--|
| Topic | Attics | | |
| Subtopic | Special Considerations | | |
| Desired Outcome | Properly restored vents minimize moisture and ice dams | | |
| Multifamily Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 4.1088.8a Pre-inspection | Conduct pre-inspection in accordance with SWS 2.0100.4 Work Area Inspection and Stabilization | Ensure safety, effectiveness, and durability of improvements | |
| 4.1088.8b Air barrier and thermal boundary | Attic ventilation will be recommended or installed only if: | Ensure presence of continuous air barrier and thermal boundary | |
| | The presence of an effective air barrier and thermal boundary between the attic and the living space is verified | | |
| | Appropriate attic sealing and proper insulation is specified as part of the work scope | | |
| | Ignition barrier and thermal boundaries are provided when foam plastic materials are used | | |
| 4.1088.8c Vent type | Attic vent types will be consistent with requirements for their specific location (e.g., exterior soffit, gable end, roof) and material and intended use (e.g., metal vent on metal roof) | Ensure vent meets proper performance characteristics for location and roofing type | |
| | Ventilation opening area and configuration will comply with applicable building code | | |
| 4.1088.8d Vent location | Placement of attic vents will be considered for proper air flow and prevention of entry of wind-driven rain or snow | Encourage proper air flow | |
| | | Minimize entry of wind-driven rain or snow | |
| 4.1088.8e Ventilation baffling | Baffling for attic soffit vents will be installed to: | Ensure vent allows proper air flow without compromising insulation performance | |
| | Ensure proper air flow | | |
| | Prevent wind washing of insulation | | |
| | Allow maximum insulation coverage | | |
| | Ensure baffle terminates above insulation | | |
| | Minimum clearance between insulation and roof deck will be 1" | | |
| 4.1088.8f Ventilation screens | All attic ventilation will have screens with noncorroding wire mesh with openings of 1/8" to prevent pest entry (e.g., birds, bats, bees) | Prevent pest entry | |
| | | | |

Existing vents that are not screened will be covered with noncorroding wire mesh with openings of 1/8"

| 4.1102.1 | | |
|---|--|--|
| Open-Cavity Wall Insulation—General | | |
| Topic | Walls | |
| Subtopic | Accessible Walls | |
| Desired Outcome | Consistent, uniform thermal boundary between the conditioned space and unconditioned space to prescribed R-value | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1102.1a Sealing | Holes and penetrations will be sealed | Prevent air leakage |
| | Bypasses will be blocked and sealed | |
| 4.1102.1b Installation | Insulation will be installed in accordance with manufacturer specifications without gaps, voids, compressions, misalignments, or wind intrusions | Insulate to prescribed R-value |
| | Insulation will be installed to prescribed R-value | |
| 4.1102.1c Pre-drywall verification | Verification of complete installation without gaps, voids, compressions, misalignments, or wind intrusions will be provided | Install insulation correctly |
| 4.1102.1d Occupant education <u>Onsite documentation</u> | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Insulation type | Confirm amount of insulation installed |
| | Coverage area | Comply with 16 CFR 460.17 |
| | R-value | |
| | Installed thickness and settled thickness (settled thickness required for loose-fill only) | |
| | Number of bags installed in accordance with manufacturer specifications (for loose-fill only) | |
| | | |

| 4.1103.1 | Dense Pack Exterior Walls | |
|--------------------------------|--|---|
| Topic | Walls | |
| Subtopic | Enclosed Walls | |
| Desired Outcome | Consistent, uniform thermal boundary between conditioned and unconditioned space to prescribed R-value of an adjoining insulated assembly | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1103.1a Exterior dense pack | Using fill tube, 100% of each cavity will be filled to a consistent density: | Eliminate voids and settling |
| | Cellulose insulation used in an enclosed cavity will be installed at 3.5 pounds per cubic foot or greater density | Minimize framing cavity air flows |
| | Blown fiberglass, mineral fiber, or rock and slag wool used in an enclosed cavity will be installed at or above the manufacturer recommended density to limit air flow that corresponds to an air permeance value of 3.5 cfm/sq. ft. at 50 pascals, as measured using BPI-102 "Standard for Air Resistance of Thermal Insulation Used in Retrofit Cavity Applications – Material Specification" or ASTM C 522, E 283, or E 2178; the number of bags installed will be confirmed and will match the number required on the coverage chart | |
| | <u>All holes and penetrations will be plugged and/or sealed</u> | |
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference | |
| 4.1103.1b Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | | Confirm amount of insulation installed Comply with 16 CFR 460.17 |
| | Coverage area | |
| | Thickness | |
| | R-value | |

| 4.1103.2 | | Additional Exterior Wall Cavities | |
|--------------------------------|---|---|--|
| Topic | Walls | | |
| Subtopic | Enclosed Walls | | |
| Desired Outcome | Properly installed insulation reduces heat flow through walls and framing cavities inaccessible to other treatments | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 4.1103.2a Location of cavities | Details remaining in or between completed wall sections will be located and accessed | Ensure the last gaps and framing edges in the thermal boundary, roof-wall joints, floor-wall joints, etc., are found and finished | |
| 4.1103.2b Sealing | Backing will be provided and all newly uncovered openings will be sealed with air barriers, foam, or mastic, maintaining all required clearances | Ensure the air barrier is connected across all accessible house elements | |
| 4.1103.2c Dense packing | Using fill tube, 100% of each cavity will be filled to a consistent density: | Eliminate voids and settling | |
| | Cellulose insulation used in an enclosed cavity will be installed at 3.5 pounds per cubic foot or greater density | Minimize framing cavity air flows | |
| | Blown fiberglass, mineral fiber, or rock and slag wool used in an enclosed cavity will be installed at or above the manufacturer recommended density to limit airflow that corresponds to an air permeance value of 3.5 cfm/sq. ft. at 50 pascals, as measured using BPI-102 "Standard for Air Resistance of Thermal Insulation Used in Retrofit Cavity Applications—Material Specification" or ASTM C 522, E 283, or E 2178; the number of bags installed will be confirmed and will match the number required on the coverage chart | | |
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference | | |
| 4.1103.2d Quality assurance | Completed wall sections will be viewed using infrared camera with blower door operating | Establish air barrier and thermal boundary | |
| | Any voids or low density areas will be drilled and re-packed | Confirm no voids or hidden air flows remain | |

| | | |
|---------------------------------------|---|--|
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference | |
| 4.1103.2e Close holes | Installation holes will be plugged as follows: | Ensure house is returned to watertight and clean condition |
| | Exterior holes will be weather barrier patched | |
| | Interior holes will be coated and patched to match original interior surface | |
| | All construction debris and dust will be collected and removed | |
| 4.1103.2f Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | | |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | |
| | R-value | Comply with 16 CFR 460.17 |

| | | |
|----------------------------------|--|--|
| 4.1103.4 | Dense Packing Blown Insulation | |
| Topic | Walls | |
| Subtopic | Enclosed Walls | |
| Desired Outcome | Maintain a consistent, uniform thermal and weather-resistant boundary between conditioned and unconditioned space to prescribed R-value of an adjoining insulated assembly | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1103.4a Worker safety | All worker safety specifications will be in accordance with SWS 2.0100.3 Worker Safety | Ensure worker safety, especially in regard to fall protection considerations and contaminants found in demolition, such as asbestos, lead, polychlorinated biphenyls, etc. |
| | Lead safety procedures in buildings built before 1980 1978 will be followed, unless approved testing method proves absence of lead based paint in surfaces that will be disturbed | |
| 4.1103.4b Occupant safety | Occupant will be notified of changes or repairs to be made | Ensure occupant safety |

| | | |
|--|---|--|
| | An occupant safety plan will be prepared and implemented | |
| 4.1103.4c Pre-inspection | Conduct pre-inspection in accordance with SWS 2.0100.4 Worker Safety | Identify and remediate pest, moisture, air leakage, and electrical problems before insulation installation |
| | | |
| | Gaps, cracks, and holes in fire separations located within the work area will be visually identified and incorporated into air sealing work scope, including those that span two conditioned or unconditioned spaces | Ensure a durable, continuous thermal boundary |
| | | |
| | Where drawings are available that identify specific fire-resistance ratings (i.e., 1 hour, 2 hour), materials and methods will be employed to preserve or restore such rating | Avoid compromising existing water control system |
| | | |
| | Where drawings are unavailable or do not identify specific fire-resistance ratings, the fire-resistance rating of the assembly may be inferred from the current construction (i.e., single 5/8 sheetrock, concrete masonry unit), and materials and methods employed will be consistent with restoring or preserving such inferred fire-resistance rating | |
| | | |
| | Repairs necessary to stabilize work areas and protect or preserve the integrity of energy improvement will be completed before work begins | |
| | | |
| | Insulation will not be installed if moisture-related issues are not resolved | |
| | | |
| Existing water control measures will be identified | | |
| | | |
| Air sealing locations on the exterior walls will be identified | | |
| | | |
| Air sealing will be completed before installing insulation | | |

| | | | |
|--|---|--|--|
| 4.1103.4d Wall access | When feasible, insulation will be installed into cavities from the exterior side of the wall | Ensure occupant health and safety | |
| | When feasible, exterior cladding at the insulation access point will be removed before creating an access hole through the sheathing | Minimize disruption within the units | |
| | Insulation access point will be created to minimize air barrier and drainage plane disruption | Avoid compromising existing water control system | |
| | Access point will be sealed to be airtight and watertight after insulation installation before reinstalling the exterior cladding | Minimize air and moisture flow through the wall system | |
| | Water management system will be repaired to function as originally intended (e.g., lapping new felt paper underneath the upper and over the lower joint of the existing felt paper) | | |
| | 4.1103.4e Sealant selection | Sealants will be compatible with their intended surfaces and applied in accordance with manufacturer specifications | Prevent intrusion of moisture and pests into the sealed assembly |
| | | Selection will be durable, pest resistant, and have a weather-appropriate seal | Prevent exposing workers or occupants to excessive VOC levels |
| Indoor sealants will be low volatile organic compound (VOC) products that meet independent testing and verification protocols, such as Green Seal GS-36, "GREENGUARD Children and Schools," or comparable certifications | | Ensure sealant meets or exceeds the performance characteristics of the assembly and is compliant with local fire code requirements | |
| Fire-resistance-rated assemblies will be provided with sealants permitted by the authority having jurisdiction and adopted building code | | | |

| | | |
|---------------------------------------|---|--|
| 4.1103.4f Exterior dense pack | Using fill tube, 100% of each cavity will be completely filled to a consistent density: | Eliminate voids and settling |
| | Cellulose insulation used in an enclosed cavity will be installed at 3.5 pounds per cubic foot or greater density | Minimize framing cavity air flow |
| | Blown fiberglass, mineral fiber, rock and slag wool, or spray foam used in an enclosed cavity will be installed in accordance at or above manufacturer recommended density to limit air flow that corresponds to an air permeance value of 3.5 cubic feet per minute/square feet at 50 pascals, as measured using the following applicable methods: | |
| | BPI-102 Standard for Air Resistance of Thermal Insulation Used in Retrofit Cavity Applications, or | |
| | Material Specification, or | |
| | ASTM C 522, or | |
| | ASTM E 283, or | |
| | ASTM E 2178 | |
| | All insulation materials used will meet ASTM E84 flame spread/smoke development rating of 25/50 | |
| | The number of bags installed will be confirmed and will match the number required on the coverage chart | |
| | Insulation will be verified to prevent visible air movement using chemical smoke at 50 pascals of pressure difference | |
| 4.1103.4g Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | |
| | R-value | Comply with 16 CFR 460.17 |

| 4.1401.1 | | |
|---|--|--|
| Band/Rim Joists—Spray Polyurethane Foam (SPF) Installation | | |
| Topic | Basements and Crawl Spaces | |
| Subtopic | Band/Rim Joists | |
| Desired Outcome | Insulate and seal all band/rim joist areas between subfloor and foundation or top plate of wall below | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1401.1a Preparation | All band/rim joist areas will be open and accessible for SPF application | Prepare all substrate surfaces for the application of SPF |
| | All surfaces where SPF is applied will be clean, dry, and free of contamination and degradation | |
| | Substrate surfaces will be wiped, blown, or vacuumed to be free of excessive dust and dirt | |
| | Grease and oil will be removed using appropriate cleaners or solvents | |
| | Moisture content of all wood substrate materials will be checked to ensure it is below 20% | |
| | | |
| 4.1401.1b Installation | SPF will be applied to desired thickness, using pass thickness maximum in accordance with manufacturer specifications, onto subfloor between floor joists and all rim/band joists | Insulate and seal floors |
| | When applied to first floor, SPF will be continuous from subfloor surface, over band/rim joist and sill plate, and in contact with foundation below, except as stipulated by classification 4.1402.1c | |
| | When applied to second story floor or above, SPF will be continuous from subfloor surface, over band/rim joist, and in contact with top plate below | |
| 4.1401.1c Fire protection | If SPF exceeds a thickness of 3", all SPF will be separated from the occupied interior space of the building with an approved thermal barrier material (typically ½" or thicker gypsum wallboard or an approved thermal barrier coating) | Provide necessary fire protection for combustible SPF insulation |
| | Application to rim/band joist up to 3" can be left exposed if the foam is Class I, unless the space is a habitable space and then cover it with drywall or another thermal barrier | |
| | Local codes will be confirmed and followed for fire protection requirements | |

| | | |
|---------------------------------------|---|--|
| 4.1401.1d Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | |
| | R-value | Comply with 16 CFR 460.17 |
| | | |

| 4.1401.2 | | |
|--|--|---|
| Band/Rim Joists – Insulation other than Spray Polyurethane Foam | | |
| Topic | Basements and Crawl Spaces | |
| Subtopic | Band/Rim Joists | |
| Desired Outcome | Closed crawl spaces insulated to achieve best thermal performance possible | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1401.2a Preparation | The rim joist, sill plate and adjacent surfaces will be sufficiently clean and free of debris to allow for the proper adhesion of any caulks, adhesives or spray foam used during installation. | Prepare all surfaces for the installation of insulation |
| 4.1401.2b Insulation installation | A foam-based insulation will be installed so as to create a continuous thermal and pressure boundary <u>or vinyl faced fiberglass batt insulation, installed tightly to the wood and sealed at all edges</u> . If rigid insulation is used, all edges will be sealed and the insulation will be installed tightly to the wood to prevent the movement of moisture throughout the assembly. Insulation will be installed in accordance with local/national code requirements and/or manufacturer’s instructions regarding flame spread. | Improve thermal performance Prevent moisture condensation on the inside of the band joist |
| 4.1401.2c Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | |
| | R-value | Comply with 16 CFR 460.17 |
| | | |

| 4.1402.1 | | |
|--|--|---|
| Closed Crawl Spaces—Wall Insulation | | |
| Topic | Basements and Crawl Spaces | |
| Subtopic | Basements and Crawl Space Walls | |
| Desired Outcome | Closed crawl spaces insulated to achieve best thermal performance possible | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1402.1a Insulation selection | A non-fibrous , fire-rated Class I insulation (<u>25 or less flame spread or Class I or Class A</u>) will be used with a minimum life expectancy of 10 years | Provide fire-safe durable insulation <u>that will not exacerbate moisture issues in the crawl space</u> |
| 4.1402.1b R-value | Regional International Energy Conservation Code (IECC) will be followed for required R-values | Improve thermal performance |
| 4.1402.1c Termite inspection gap | Where termite pressure exists, a 3" inspection gap will be maintained from the top of the insulation to the bottom of any wood | Allow for termite detection |
| 4.1402.1d Attachment | Insulation will be attached with a durable connection <u>better than or</u> equal to or better than manufacturer specifications | Prevent insulation from detaching from the foundation wall |
| 4.1402.1g Onsite documentation | A dated receipt signed by the installer will be provided that includes: | Document job completion to contract specifications |
| | | |
| | Coverage area | Confirm amount of insulation installed |
| | Thickness | |
| | R-value | Comply with 16 CFR 460.17 |

| | | |
|-------------------------------------|---|--|
| 4.1402.2 | Basement Wall Insulation—No Groundwater Leakage | |
| Topic | Basements and Crawl Spaces | |
| Subtopic | Basements and Crawl Space Walls | |
| Desired Outcome | Basement insulation improves thermal performance and ensures sufficient drying potential | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 4.1402.2a R-value | Regional IECC will be followed for required R-values | Improve thermal performance of the basement and living space |
| 4.1402.2b Air barrier | A continuous air barrier will be installed on the warm side of the insulation | Prevent condensation on the basement wall |
| 4.1402.2c Vapor permeability | When absorbent insulation materials are installed, assembly will remain vapor <u>semi-im</u> permeable to the interior in all climate zones except Zone 7 | Provide drying potential to the basement |

| | | |
|--|---|--|
| 5.3003.2 | Combustion Analysis of Oil-Fired Appliances | |
| Topic | Forced Air | |
| Subtopic | System Assessment and Maintenance | |
| Desired Outcome | Analysis on critical components and operations completed in accordance with industry and manufacturer specifications <u>to ensure equipment operates as designed, safely, efficiently and is durable.</u> | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. <u>If new installation or replacement is necessary, ANSI / ACCA 5 Q1 HVAC Quality Installation Specification will be followed.</u> | |
| Manufactured Housing, Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| <u>5.3003.2a</u> Oil System: filter | <u>Filter will be present, clean, and leak free</u> | <u>Ensure oil filter is present and functional.</u> |
| 5.3003.2a-2b Oil system: n Nozzle size | Nozzle size, <u>angle, and spray pattern</u> will be correct for design input and within equipment firing rate of the heating system manufacturer. <u>Position of nozzle and electrodes will be in accordance with manufacturer specifications</u> | Ensure equipment <u>is outfitted with the correct nozzle per manufacturer guidelines.</u> operates as designed Ensure equipment operates safely Ensure equipment operates efficiently Ensure equipment is durable |
| 5.3003.2b-2c Fuel pressure | Measurement will be verified in accordance with manufacturer specifications | Ensure <u>correct oil pump pressure for nozzle installed and at OEM's specified values per ACCA.</u> equipment operates as designed Ensure equipment operates safely |

| | | |
|--|---|--|
| | | <p>Ensure equipment operates efficiently</p> |
| | | <p>Ensure equipment is durable</p> |
| <p><u>5.3003.2d</u> Place appliance in operation</p> | <p><u>Heating equipment will be placed in operation in accordance with applicable standards and manufacturer specifications when available</u></p> | <p><u>Prepare equipment for combustion analysis tests.</u></p> |
| <p>5.3003.2e-2f Oil system: steady state efficiency (SSE)</p> | <p>Measurement will be verified in accordance with manufacturer specifications</p> | <p><u>Determine whether steady state efficiency is within manufacturer range.</u> Ensure equipment operates as designed</p> |
| | | <p>Ensure equipment operates safely</p> |
| | | <p>Ensure equipment operates efficiently</p> |
| | | <p>Ensure equipment is durable</p> |
| <p>5.3003.2d-2e Oil system: smoke Smoke test (This test must be conducted before any combustion testing is completed)</p> | <p><u>Smoke test will be conducted before any combustion testing is completed</u></p> <p>Smoke spot reading will be in accordance with burner manufacturer specifications</p> | <p>Ensure equipment operates as designed</p> <p><u>Determine whether equipment is operating within acceptable range according to smoke test and call for action if needed.</u></p> |
| | <p>If smoke test is more than actionable levels, specify a clean and tune</p> | <p>Ensure equipment operates safely</p> |
| | | <p>Ensure equipment operates efficiently</p> |
| | | <p>Ensure equipment is durable</p> |
| <p>5.3003.2e-2g Net stack temperature</p> | <p>Net stack temperature will be measured and verified in accordance with manufacturer specifications</p> | <p><u>Determine whether net stack temperature is within manufacturer's</u></p> |

| | | |
|---|---|--|
| | | <p>recommended range. Ensure equipment operates as-designed</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment is durable</p> |
| <p>5.3003.2f-2h Carbon dioxide (<u>CO2</u>) and oxygen (<u>O2</u>)</p> | <p>Measurement will be verified in accordance with industry manuals and manufacturer specifications</p> | <p><u>Verify combustion performance of equipment is within manufacturer recommended range based on CO2 and O2 readings.</u> Ensure equipment operates as-designed</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment is durable</p> |
| <p>5.3003.2g-2i Excess <u>combustion</u> air</p> | <p>Excess <u>combustion</u> air will be calculated and shown to be in accordance with manufacturer specifications</p> | <p><u>Verify combustion performance of equipment is within manufacturer recommended range based on excess combustion air readings.</u> Ensure equipment operates as-designed</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment is durable</p> |

| | | |
|---|--|---|
| | | |
| 5.3003.2h-2j CO in flue gas | <p>Undiluted flue gases will be checked with a calibrated combustion analyzer</p> <p><u>Measure CO and recommend actions to ensure that CO in the undiluted flue gas will be less than 400 ppm air-free</u></p> | <p><u>Ensure CO in undiluted flue gas is less than 400 ppm air-free.</u> Ensure equipment operates as designed</p> |
| | <p>For CO levels exceeding 200 ppm as measured, or 400 ppm air free measurement, service will be provided to reduce CO to below these levels (unless CO measurement is within manufacturer specifications)</p> | <p>Ensure equipment operates safely</p> |
| | | <p>Ensure equipment operates efficiently</p> |
| 5.3003.2k <u>Testing/inspection holes</u> | <p><u>All testing and inspection holes will be sealed with approved materials</u></p> | <p>Ensure equipment is durable</p> <p><u>Ensure equipment:</u></p> <ul style="list-style-type: none"> - <u>Operates as designed</u> - <u>Operates safely</u> - <u>Operates efficiently</u> - <u>Is durable</u> |

| 5.3003.3 | | Evaluating Air Flow | |
|--|---|---------------------------------------|--|
| Topic | Forced Air | | |
| Subtopic | System Assessment and Maintenance | | |
| Desired Outcome | Air flow is properly tested | | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | | |
| Single-Family Homes, Manufactured Housing | | | |
| Title | Specification(s) | Objective(s) | |
| 5.3003.3a Total air flow | Total system air flow will be measured by one of the following methods : | Ensure equipment operates as designed | |
| | Temperature rise | Ensure equipment operates efficiently | |
| | Flow plate | | |
| | Fan depressurization device (e.g., Duct Blaster®, DucTester®) | Ensure equipment provides comfort | |
| | | Ensure equipment operates safely | |
| | | Ensure equipment is durable | |
| | | | |
| 5.3003.3b External static pressure | External static pressure will be in accordance with manufacturer specifications | Ensure equipment operates as designed | |
| | | | |
| | | Ensure equipment operates efficiently | |
| | | | |
| | | Ensure equipment provides comfort | |
| | | Ensure equipment operates safely | |
| 5.3003.3c Pressure | Pressure drop across cooling coils will be in accordance with manufacturer specifications | Ensure equipment operates as designed | |
| | | | |
| | | Ensure equipment operates efficiently | |
| | | | |
| | | Ensure equipment provides comfort | |
| | | | |
| | | Ensure equipment operates safely | |
| | | | |

| | | |
|--|--|---------------------------------------|
| | | Ensure equipment is durable |
| 5.3003.3d Pressure drop: filter | Pressure drop across filter will be in accordance with manufacturer specifications | Ensure equipment operates as designed |
| | | Ensure equipment operates efficiently |
| | | Ensure equipment provides comfort |
| | | Ensure equipment operates safely |
| | | Ensure equipment is durable |
| | | |
| 5.3003.3e Balancing room flow: new ductwork | Air flow will be measured at each register to ensure proper air flow delivery | Ensure equipment operates as designed |
| | | Ensure equipment operates efficiently |
| | | Ensure equipment provides comfort |
| | | Ensure equipment operates safely |
| | | Ensure equipment is durable |
| | | |
| 5.3003.3f Supply wet bulb and dry bulb | Supply wet bulb and dry bulb air temperatures will be recorded | Ensure equipment operates as designed |
| | | Ensure equipment operates efficiently |
| | | Ensure equipment provides comfort |
| | | Ensure equipment operates safely |
| | | Ensure equipment is |
| | | |

| | | |
|---|--|--|
| | | <p>durable</p> <p>Ensure equipment operates as designed</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment provides comfort</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment is durable</p> |
| <p>5.3003.3g Return wet bulb and dry bulb</p> | <p>Return wet bulb and dry bulb air temperatures will be recorded</p> | <p>Ensure equipment operates as designed</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment provides comfort</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment is durable</p> |
| <p>5.3003.3h Temperature rise: gas and oil furnaces only</p> | <p>Temperature rise between the supply and return will be in accordance with manufacturer specifications</p> | <p>Ensure equipment operates as designed</p> <p>Ensure equipment operates efficiently</p> <p>Ensure equipment provides comfort</p> <p>Ensure equipment operates safely</p> <p>Ensure equipment is durable</p> |

| 5.3003.5 | | Refrigerant Line Inspection | |
|---|---|---|--------------------------------------|
| Topic | Forced Air | | |
| Subtopic | System Assessment and Maintenance | | |
| Desired Outcome | Refrigerant lines properly installed | | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 5.3003.5a Insulation | All suction or liquid vapor refrigerant lines will be insulated to a minimum of R-4 | Ensure refrigerant lines do not gain excessive heat, <u>or cause condensation to occur inside the building envelope</u> | |
| | Vapor or high -side or liquid refrigerant lines will not be insulated unless specified by the equipment's manufacturer | | |
| | Suction lines will be insulated to a minimum of R-4 | | |
| 5.3003.5b Ultraviolet (UV) protection of insulation | If exposed to sunlight, refrigerant line insulation will be protected from UV degradation in accordance with manufacturer specifications, 2012 IRC N1103.3.1, or local code | Install insulation so it does not degrade | |
| 5.3003.5c Sizing | Refrigerant lines will be sized to meet manufacturer specifications for the installed equipment | Ensure system moves appropriate volume of refrigerant | |
| 5.3003.5d Installation quality | Refrigerant lines will be installed without kinks, crimps, or excessive bends | Ensure system moves appropriate volume of refrigerant | |
| 5.3003.5e Support | Refrigerant lines will be routed, supported, and secured to house in a manner that protects the line from damage by workers or occupants | Ensure refrigerant lines do not move, vibrate, or sag | |
| | | Protect lines from damage | |
| Manufactured Housing | | | |
| Title | Specification(s) | Objective(s) | |
| 5.3003.5a Insulation | All suction or liquid vapor refrigerant lines will be insulated to a minimum of R-4 | Ensure refrigerant lines do not gain excessive heat, <u>or cause condensation to occur inside the building envelope</u> | |
| | Vapor or high -side or liquid refrigerant lines will not be insulated unless specified by the equipment's manufacturer | | Prevent energy loss and condensation |
| | Suction lines will be insulated to a minimum of R-4 | | |

| | | |
|--|---|---|
| | For mixed humid, hot humid, and marine climates, heating and cooling refrigerant lines will be insulated | |
| 5.3003.5b Ultraviolet (UV) protection of insulation | If exposed to sunlight, refrigerant line insulation will be protected from UV degradation in accordance with manufacturer specifications, 2012 IRC N1103.3.1, or local code | Install insulation so it does not degrade |
| 5.3003.5c Sizing | Refrigerant lines will be sized to meet manufacturer specifications for the installed equipment | Ensure system moves appropriate volume of refrigerant |
| 5.3003.5d Installation quality | Refrigerant lines will be installed without kinks, crimps, or excessive bends | Ensure system moves appropriate volume of refrigerant |
| 5.3003.5e Support | Refrigerant lines will be routed, supported, and secured to house in a manner that protects the line from damage by workers or occupants | Ensure refrigerant lines do not move, vibrate, or sag |
| | | Protect lines from damage |

| | | |
|--|---|---|
| 5.3003.14 | Combustion Analysis of Gas-Fired Appliances (LP and Natural Gas) | |
| Topic | Forced Air | |
| Subtopic | System Assessment and Maintenance | |
| Desired Outcome | Analysis of critical components and operations completed in accordance with industry and manufacturer specifications | |
| Single-Family Homes, Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |
| 5.3003.14a Place appliance in operation | Heating equipment will be placed in operation in accordance with applicable NFPA standards and manufacturer specifications when available | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.14b Gas pressure | Measurement will be verified by a certified professional in accordance with fuel type and manufacturer specifications | Ensure equipment: - Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.14c Carbon dioxide (CO2) and oxygen (O2) | Measurement will be verified in accordance with industry manuals (e.g., Testo, Bacharach) | Ensure equipment: Operates as designed Operates safely |

| | | |
|--|--|---|
| | | Operates efficiently Is durable |
| 5.3003.14d Excess combustion air | Excess combustion air will be calculated and verified in accordance with industry manuals (e.g., Testo, Bacharach) | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.14e Carbon monoxide (CO) in flue gas | CO in the undiluted flue gas will be less than 100 <u>400 ppm air-free</u> | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.14f <u>Gas pressure</u> | <u>If fault has been determined in the preceding steps, then measurement will be verified by a certified professional in accordance with fuel type and manufacturer specifications</u> | <u>Ensure equipment:</u> <u>Operates as designed</u> <u>Operates safely</u> <u>Operates efficiently</u> <u>Is durable</u> |
| 5.3003.14g Testing/inspection holes | All testing and inspection holes will be sealed with manufacturer approved materials | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |

| | | |
|--|--|----------------------|
| 5.3003.15 | Combustion Analysis of Oil-Fired Appliances | |
| Topic | Forced Air | |
| Subtopic | System Assessment and Maintenance | |
| Desired Outcome | Analysis of critical components and operations completed to industry and manufacturer specifications | |
| Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |
| 5.3003.15a Oil system: smoke test | Smoke test will be conducted before any combustion testing is completed | Ensure equipment: |
| | Smoke spot reading will be in accordance with burner manufacturer specifications | Operates as designed |

| | | |
|---|--|----------------------|
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15b Oil system: nozzle | Nozzle size, angle, and spray pattern will be correct for design input and within equipment firing rate of the heating system manufacturer | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15c Oil filter | Filter will be present, clean, and leak free | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15d Fuel pressure | Measurement will be verified in accordance with manufacturer specifications | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15e Oil system: steady state efficiency (SSE) | Measurement will be verified in accordance with manufacturer specifications | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15f Net stack temperature | Net stack temperature will be measured and verified in accordance with manufacturer specifications | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15g Carbon dioxide (CO2) and oxygen (O2) | Measurement will be verified in accordance with industry manuals (e.g., Testo, Bacharach) | Ensure equipment: |
| | | Operates as designed |
| | | Operates safely |
| | | Operates efficiently |
| | | Is durable |
| | | |
| 5.3003.15h Excess combustion air | Excess combustion air will be calculated and shown to be <u>minimized</u> in accordance with | Ensure equipment: |
| | | |

| | | |
|-------------------------------------|---|--|
| | industry manuals (e.g., Testo, Bacharach) <u>best practices</u> | Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.15i CO in flue gas | CO in the undiluted flue gas will be less than 100 <u>400 ppm air-free</u> | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |
| 5.3003.15j Testing/inspection holes | All testing and inspection holes will be sealed with approved materials | Ensure equipment: Operates as designed Operates safely Operates efficiently Is durable |

| | | |
|-------------------------------|---|---|
| 5.3104.2 | Maintenance: Gas Boiler Service Inspection | |
| Topic | Hydronic Heating (Hot Water and Steam) | |
| Subtopic | Equipment Maintenance, Testing, and Repair | |
| Desired Outcome | Boiler service improves safety, efficiency, and performance | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 5.3104.2a Visual inspection | The following conditions will be assessed by a licensed contractor: | Observe general conditions to determine needed repairs or maintenance |
| | Water, steam, and fuel leaks | |
| | Damaged or missing pipe insulation | |
| | Venting issues—draft and condensation (e.g., soot, rusting of flue pipe, burned paint or wires, efflorescence) | |
| | Corrosion (e.g., rust, mineral deposits) | |
| | General condition of components | |
| 5.3104.2b Appliance gas valve | When replacement is necessary, gas valve will be removed and replaced according to manufacturer specifications | Provide gas to burner when there is a call for heat |

| | | |
|---|--|---|
| | | Control volume of gas for burner |
| | | Ensure the safe shut off of gas at the end of a call for heat |
| 5.3104.2c Ignition system | Components of ignition system will be repaired or replaced in accordance with manufacturer specifications | Do not allow flow of main burner gas without proof of ignition |
| 5.3104.2d Main gas burners | Problems that may interfere with flame (e.g., dust, debris, misalignment) will be cleaned, vacuumed, and adjusted | Produce combustion in a safe, clean, and efficient manner |
| 5.3104.2e Venting | Flue gases will be removed from the venting system in accordance with 2012 IRC G2427 or per manufacturer specifications | Ensure the safety and durability of the venting system |
| 5.3104.2f Flue gas testing | Undiluted flue gases will be checked with a calibrated combustion analyzer in accordance with BPI 1200 or other approved standard 1100-T-2012 | Confirm that combustion occurs safely with maximum efficiency |
| | If combustion is not in compliance with BPI-1100-T-2012 the referenced standard , diagnostics and adjustments will be referred to a qualified technician done to meet manufacturer specifications or local codes | |
| 5.3104.2g Combustion efficiency checks | Undiluted flue gases will be checked with a calibrated combustion analyzer in accordance with accepted protocol to determine if acceptable boiler efficiency is being maintained | Increase the operational efficiency of the system |
| | If boilers are found to be out of compliance, a combustion analysis will be administered and minimum stack temperature will be in accordance with manufacturer specifications | Improve occupant comfort |
| 5.3104.2h Occupant health | All homes will have a carbon monoxide (CO) alarm | Ensure ambient CO does not exceed acceptable levels after completion of work |
| 5.3104.2i Occupant education | Occupants will be educated on the operation and maintenance of the carbon monoxide (CO) alarm | Ensure occupant is informed of the safe and efficient operation and maintenance of the work performed |
| | Completed work and recommended maintenance will be reviewed | |

| | | |
|-----------------|---|--|
| 6.6004.2 | Individual Exhaust Fan Serving Multiple Rooms Within Single Dwelling Unit (All Building Types) | |
| Topic | Exhaust | |

| | | |
|-------------------------------------|--|--|
| Subtopic | Exhaust Ventilation Systems | |
| Desired Outcome | Multiport fan system installed to provide required ventilation | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 6.6004.2a Pre-inspection | Specifications will be field verified as appropriate to site conditions by installer | Ensure appropriate design for installation |
| 6.6004.2b Air flow | ASHRAE 62.2 and local code requirements should be followed for identifying design airflow rates within apartment dwelling units. | Exhaust sufficient air from desired locations to the outdoors |
| | All other areas will follow local code requirements and/or ASHRAE 62.1-2010 requirements | |
| | Air flows will be measured in accordance with ANSI/ACCA Standard 5 or ANSI/ASHRAE Standard 111 and adjusted to meet design requirements | |
| 6.6004.2c Outlet termination | Outlet will be terminated outside of the building shell and will have a louvered cover and bird screen | Direct exhaust to the outdoors and prevent re-entry |
| | Minimum distance of exhaust outlet from any doors, windows, or outside air intakes shall be in conformance with the applicable building code | Prevent entry of weather and pests into building shell |
| | Outlet will be sealed to prevent water intrusion and exhaust air leakage into building cavities | Ensure occupant health and safety |
| 6.6004.2d Wiring | Wiring will be installed by a properly licensed contractor | Prevent an electrical hazard |
| | Wiring will be installed in accordance with original equipment manufacturer specifications, and local and national electrical and mechanical codes | |
| | Refer to NFPA 70: National Electrical Code for installation requirements | |
| 6.6004.2e Access | Fan and service switch will be accessible for maintenance | Ensure unit and service switch are accessible for maintenance or replacement |
| 6.6004.2f Fan mounting | Fan will be oriented so the equivalent length of the duct run is as short as possible | Ensure short duct runs to achieve optimum air flows |
| | | |

| | | |
|---|--|--|
| | Fan will be mounted securely in accordance with manufacturer specifications and local code requirements (in terms of seismic restraints, vibration, and noise control) | Ensure mounting is installed securely |
| | Fan will be isolated from the building framing unless specifically designed to be directly attached | Ensure fan housing or building framing does not shake, rattle, or hum when operating |
| | Fan will be installed remotely by ducting from intake grilles | Minimize noise |
| 6.6004.2g Backdraft dampers (required in intermittent systems) | A backdraft damper will be installed between the fan and the exterior unless the system operates continuously | Prevent reverse air flow when the system is off |
| | A backdraft damper will be installed in any duct serving any room with a separate exhaust (e.g., dryer) | Prevent spread of contaminants between rooms |
| 6.6004.2h Combining intake ducts | All individual intake ducts will be combined on the intake side of fan (e.g., Y-fitting, T-fitting, collector box) | Exhaust air from desired locations to the outdoors |
| 6.6004.2i Duct connections | Ducts will be connected and sealed to applicable intakes, collector box, fan, and termination fitting | Exhaust air from desired locations to the outdoors |
| | Ducts will be connected and sealed in accordance with the applicable code adopted by the jurisdiction | Preserve integrity of the duct system and building envelope |
| 6.6004.2j Insulation | All components outside of the thermal envelope will be insulated to a minimum of R-8 or equivalent to local codes | Preserve integrity of the duct system |
| | | Prevent condensation in ductwork |
| | | Prevent heat loss |
| 6.6004.2k Boot to interior surface seal | Register boot will be sealed to interior surfaces with sealants compatible to their intended surfaces | Prevent air leakage around boot |
| | Sealants will be continuous and meet fire barrier specifications | Ensure a permanent seal to the building air barrier |
| | Boots will be connected and sealed in accordance with the applicable code adopted by the jurisdiction | Prevent a fire hazard |
| 6.6004.2l Preventing air leakage caused by exhaust fans | Walls, ceilings, and floors will be sealed to separate any occupied space from any unconditioned spaces and adjacent dwelling units | Ensure occupant health and safety |

| | | |
|--|---|--|
| | Refer to ASHRAE 62.2-2010 Section 6.1 | Prevent air leakage into the building from other spaces (e.g., adjacent dwelling units, garages, unconditioned crawl spaces, unconditioned attics) |
| 6.6004.2m Balance and flow | Air flows will be measured and adjusted to match to the design specification | Achieve the desired air flows to and from the desired locations |
| 6.6004.2n Combustion zone testing | Pressure effects caused by fans will be assessed and corrected when found outside of combustion safety standards | Ensure safe operation of combustion appliances |
| 6.6004.2o Fire dampers | Fire dampers must be accessible for inspection and/or testing by the local authorities; if fire dampers are not accessible from a grill or register, an access door in the ductwork is required | Ensure access to fire dampers for safe operation |
| | Sealing activities will not interfere with the operation of fire dampers, balancing dampers, or backdraft dampers | Minimize static pressure |
| | Type B fire dampers will be used as required by fire code | Maximize air flow |
| 6.6004.2p Occupant/property manager education | Occupant/property manager will be educated on purpose and value of system | Ensure occupant health and safety |
| | Property manager will be instructed on all maintenance procedures | Preserve integrity of system |

| 6.6102.3 Intake for Ventilation Air to Forced Air System Used for Heating or Cooling | | |
|---|---|---|
| Topic | Supply | |
| Subtopic | Components | |
| Desired Outcome | Intake reduces pollutant entry, is easily maintained, has proper flow, and enhances house durability | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | |
| Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| 6.6102.3a Forced air system requirements | Existing forced air system leakage to outside will be less than 10% of the air handler flow when measured at 25 pascals with reference to outside | Reduce migration of pollutants |
| | Any portion of the return located inside the combustion appliance zone will be air sealed | |
| | Zone will be air sealed | |
| 6.6102.3b Wiring | Wiring will be installed in accordance with original equipment manufacturer specifications and local and national electrical and mechanical codes | Prevent an electrical hazard |
| 6.6102.3c Access | Motorized damper and service switch will be accessible for maintenance in accordance with required code or authority having jurisdiction | Ensure accessibility for maintenance |
| 6.6102.3d Mounting intake duct | Ventilation duct will be attached as close to the HVAC system's fan as possible while remaining in compliance with HVAC manufacturer specifications | Ensure short duct run to achieve optimum air flow |
| | Filtration of ventilation air will be provided before passing through the thermal conditioning components | Preserve integrity of the duct system and building envelope |
| | Duct will be connected to intake fitting | |
| | Connection and seal will be performed according to supply duct detail | |
| | | |
| 6.6102.3e Motorized damper | A motorized damper or equivalent technology will be installed between the intake fitting and the return side of the air handler | Prevent air flow when none is desired |
| | Air flow will be provided by sequenced operation of the damper or equivalent technology | |

| | | |
|-------------------------------------|--|---|
| 6.6102.3f Intake filter | An accessible filter will be installed | Ensure occupant health and safety |
| | Filter will be able to remove contaminants consistent with at least minimum efficiency reporting value (MERV) 6 or better when tested in accordance with ANSI/ASHRAE 52.2-2007 | Preserve integrity of the building envelope |
| | Filter or air cleaning systems that intentionally produce ozone will not be allowed | |
| 6.6102.3g Occupant education | Occupant will be educated on how and when to change filter | Protect occupant health and safety |
| | | Preserve integrity of the building envelope |

| | | |
|--|---|---|
| 6.6201.1 | Installed-System-Air-Flow | - |
| Topic | Whole-Building-Ventilation | - |
| Subtopic | Air-Flow-Requirements | - |
| Desired-Outcome | Installed-system-air-flow-meets-required-standard | - |
| - | | |
| Single-Family-Homes | | |
| Title | Specification(s) | Objective(s) |
| 6.6201.1a Separate-exhaust-for-all-baths-and-kitchens-plus-primary-ventilation | Air-flows-will-be-measured-and-adjusted-to-meet-the-current-version-of-ASHRAE-62.2-and-in-compliance-with-the-authority-having-jurisdiction. See [no-lexicon]Calculation-of-the-Infiltration-Credit [/no-lexicon]for calculation information and examples | Provide-sufficient-flows-in-accordance-with-current-ventilation-standards |
| 6.6201.1b Separate-exhaust-for-all-baths-and-kitchens-sufficient-to-meet-primary-ventilation-requirements | Air-flows-will-be-measured-and-adjusted-to-meet-the-current-version-of-ASHRAE-62.2-and-in-compliance-with-the-authority-having-jurisdiction. See [no-lexicon]Calculation-of-the-Infiltration-Credit [/no-lexicon]for calculation information and examples | Provide-sufficient-flows-per-current-ventilation-standards |
| 6.6201.1c Single-additional-fan-to-meet-all-ventilation-requirements | Air-flows-will-be-measured-and-adjusted-to-meet-the-current-version-of-ASHRAE-62.2-and-in-compliance-with-the-authority-having-jurisdiction. See [no-lexicon]Calculation-of-the-Infiltration-Credit [/no-lexicon]for calculation information and examples | Provide-sufficient-flows-in-accordance-with-current-ventilation-standards |

| 6.6202.3 | Airflow Control Devices (All Building Types) | |
|------------------------------|---|---|
| Topic | Whole Building Ventilation | |
| Subtopic | Components | |
| Desired Outcome | Efficient and balanced distribution system | |
| Multifamily Homes | | |
| Title | Specification(s) | Objective(s) |
| 6.6202.3a Pre-inspection | Specifications will be field verified as appropriate to site conditions by installer (e.g., duct size, type, shape, register type, duct static pressure) | Ensure appropriate design for installation |
| | Access to all dwelling units and elements of distribution system will be ensured by installer | |
| 6.6202.3b Preparation | Duct cleaning, <u>when performed</u> , will be performed in compliance with ANSI/ACCA 6 HVAC System Cleanliness-2007 | Establish preconditions for installing flow control device |
| | Register cleaning or replacement will be performed as specified | Ensure health and safety of occupant |
| | Duct sealing will be performed as specified | |
| | Stack pressures will be verified for proper operation of flow control device | |
| | Presence and type of dampers and smoke control devices will be identified, and installer will ensure the installation of the air flow device will not interfere with proper operation | |
| | | |
| 6.6202.3c Material selection | Appropriate selection of air flow regulator or orifice will be confirmed by installer; if custom design is required, it will be determined by installer | Ensure sealants and materials meet or exceed the performance characteristics required of the assembly (e.g., fire rating) |
| | Registers will be compatible with selected flow control device | Ensure conditions exist for effective installation of flow control device |
| | | |

| | | |
|--|--|---|
| | Gasketing or transition system will be compatible with selected flow control device and existing duct components | Ensure conditions exist for the flow control device to meet the design specifications |
| | Sealants and materials will be compatible with their intended surfaces and applied in accordance with manufacturer specifications | |
| | Duct sealants will be UL 181 compliant | |
| | Sealants and materials will be continuous and in accordance with fire barrier specifications | |
| 6.6202.3d Installation | Transition or adapter will be securely fastened and sealed in accordance with manufacturer specifications | Achieve specified design flows |
| | Flow control device will be installed with proper orientation and in accordance with manufacturer specifications | Provide a durable and secure installation |
| | Adjustable devices will be set to preliminary balancing position | |
| 6.6202.3e Balance and flow | Air flows will be measured and adjusted to match to the design specification in accordance with ANSI/ACCA Standard 5 or ANSI/ASHRAE Standard 111 | Achieve the desired air flows to and from the desired locations |
| 6.6202.3f Verification | Final visual inspection of flow control installation and installer documentation will be completed | Ensure the performance of the ventilation system |
| | Continued operation of dampers and smoke control devices will be verified | Ensure occupant health and safety |
| 6.6202.3g Occupant/property manager education | Occupant/property manager will be educated on how the system works and its purpose | Ensure the durability of the ventilation system |
| | Occupant/property manager will be educated on how to inspect flow control device upon unit turnover | |

| 6.6202.9 | | Filtration for Fan-Powered (Active) Systems | |
|---|--|---|--|
| Topic | Whole Building Ventilation | | |
| Subtopic | Components | | |
| Desired Outcome | Indoor air quality (IAQ) improved and equipment efficiency maintained | | |
| Single-Family Homes, Multifamily Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 6.6202.9a Pre-inspection | Specifications will be field verified as appropriate to site conditions by installer | Ensure appropriate design for installation | |
| 6.6202.9b Selection | All mechanically supplied outdoor air will pass through filter before conditioning | Ensure outdoor air is filtered before entering occupied space | |
| | Filters and filter racks/holders will have a rating of minimum efficiency rating value 6 or higher when tested in accordance with ASHRAE 52.2- 2007 | Ensure occupant health and safety | |
| | Pressure drop across filter will match equipment capabilities | | |
| | Filter systems that produce ozone will not be allowed | | |
| | | | |
| 6.6202.9c Installation | Filter will be located and installed to facilitate access and regular service by occupant/maintenance staff | Prevent air bypass of filter | |
| | Filter will be located on the inlet side of the equipment fan | Allow for proper maintenance and replacement | |
| | Filter access panel will include gasket or comparable sealing mechanism and fit snugly against exposed edge of filter when closed to prevent air bypass | | |
| | Filter plenum construction will be airtight and sealed to adjoining ductwork | | |
| 6.6202.9d Occupant/property manager education | Occupant/property manager will be instructed on proper maintenance procedures and replacement schedule | Ensure continued performance of equipment efficiency and IAQ | |

| | | |
|--|---|--|
| 6.6204.1 | Commissioning Existing Exhaust or Supply Ventilation Systems | |
| Topic | Whole Building Ventilation | |
| Subtopic | Equipment <u>System</u> Evaluation | |
| Desired Outcome | Verify proper operation of existing systems, <u>installed system air flow meets required standard and provides continuous ventilation for background pollutant sources</u> | |
| Manufactured Housing, Single-Family Homes | | |
| Title | Specification(s) | Objective(s) |
| <u>6.6204.1a Identification</u> | <u>Identify whole building ventilation strategy that was installed in the home, based on options described in current version of ASHRAE 62.2, e.g., exhaust only, supply only, balanced, combining local and whole home ventilation delivery, incorporating infiltration credit, etc.</u> | <u>Ensure suitable whole building ventilation strategy is installed. Identify testing requirements to determine installed system air flow.</u> |
| 6.6204.1a-1b Systems check <u>Equipment inspection</u> | Visual inspection will be performed and documented for: <u>Visually inspect and document status of:</u> | Evaluate systems <u>equipment</u> |
| | Electrical connections | |
| | Name plate (rated sone and flow) | |
| | Damper operation (internal and external) | |
| | Motor cleanliness | |
| | Ducts: | |
| | Connections (proper materials, sealed and connected) | |
| | Insulation | |
| | Support | |
| | Sizing | |
| | Termination | |
| <u>6.6204.1c Pathway inspection</u> | <u>Visually inspect and document status of ducting or other airflow pathways to ensure proper:</u> <ul style="list-style-type: none"> • <u>Connections (proper materials, sealed and connected)</u> • <u>Insulation</u> • <u>Support</u> • <u>Sizing, and</u> • <u>Termination locations and fittings.</u> <u>Verify proper damper operation</u> | <u>Preserve integrity of building envelope. Effectively move air along selected pathways.</u> |
| 6.6204.1b-1d Measurement and Adjustment <u>Verify flow rate</u> | Calibrated <u>Using a calibrated device, will be used to test for flow measurement</u> <u>measure air flow of all necessary components, including building air</u> | <u>Provide sufficient air flows per current ventilation standards.</u> |

| | | |
|--|---|---|
| | <p><u>leakage when relevant.</u> <u>Adjust ventilation equipment air flows as necessary to meet the ventilation rates required by the current version of ASHRAE 62.2</u></p> | <p><u>Verify suitable performance of installed ventilation strategy.</u> <u>Ensure proper flow</u></p> |
| 6.6204.1e-1e Work order | <p><u>Develop Wwork order will be developed as necessary <u>to correct deficiencies identified during inspections and measurement</u> in accordance with systems check and flow rate</u></p> | Correct deficiencies |
| | | Ensure proper operation |
| <p>6.6204.1d Total ventilation airflow <u>6.6204.1f Occupant education</u></p> | <p>Total exhaust and/or supply system ventilation airflow will be measured <u>Instruct occupant on purpose, use and maintenance of ventilation, and typical signs that ventilation is needed, e.g., condensation on windows</u></p> | <p>Ensure airflow is as designed <u>Occupant understands benefits of good indoor air quality and can operate ventilation equipment as needed.</u></p> |

| 6.6205.1 | | Manufactured Housing Exhaust-Only Strategies | |
|---|---|---|--|
| Topic | Whole Building Ventilation | | |
| Subtopic | Exhaust-Only System | | |
| Desired Outcome | Provide primary ventilation for common spaces | | |
| Manufactured Housing | | | |
| Title | Specification(s) | Objective(s) | |
| 6.6205.1a Assessment | Assessment will be done using ASHRAE 62.2 standard: | Determine the ventilation needs of the whole house | |
| | Blower door test | | |
| | Fan flow measurements | | |
| | Calculations | | |
| 6.6205.1b Selection | Fan type will be capable of continuous operation and selected in accordance with ASHRAE 62.2 for: | Determine proper fan selection | |
| | Sizing | Minimize energy consumption during fan operation | |
| | Climate considerations | | |
| | Control strategy | | |
| | Sone rating | | |
| | Durability | | |
| | Fan will be ENERGY STAR qualified | | |
| 6.6205.1c Location | No resistance greater than 3 pascals will exist between fan intake location with reference to the common area | Ensure fresh air distribution to common areas | |
| | Exhaust ventilation for common spaces will not be installed in bathrooms or bedrooms | | |
| 6.6205.1d Climate considerations | ASHRAE 62.2 will be referenced for climate considerations | Maintain building durability | |
| | Whole house mechanical net exhaust flow for hot-humid climate will not exceed 7.5 cubic feet per minute/100 square feet | Protect occupant health | |
| 6.6205.1e Combustion Appliance Zone (CAZ) testing | CAZ test will be performed where combustion appliances are utilized, where applicable | Identify possible conditions that can cause unsafe equipment operating conditions | |

| | | |
|--|---|---|
| 6.6205.1f Occupant education | Occupant will be educated on: | Ensure occupant is educated on the safe and efficient operation of the system |
| | Purpose of the ventilation system | Deliver intended air exchange |
| | Proper operation and use of controls | |
| | Cost and benefit of system | |
| | Manual shut off | |
| | A label indicating the presence and purpose of the ventilation system will be included or a copy of the system operation guide will be posted at the electrical panel | |
| | Operation guide or label will be permanently attached and in full sight | |
| 6.6205.1g Total exhaust airflow | Total exhaust system airflow will be measured | Ensure exhaust airflow is as designed |

| 6.6288.1 | | Sound-Rating Limits | |
|---|--|----------------------------|--|
| Topic | Whole Building Ventilation | | |
| Subtopic | Special Considerations | | |
| Desired Outcome | Systems operate as quietly as possible | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 6.6288.1a Primary ventilation system or any continuously operating fan | System shall be rated for sound in accordance with current ASHRAE 62.2 standard | Minimize noise | |
| 6.6288.1b Intermittent local ventilation system | Local ventilation will be rated for sound at a maximum of 3 sone, unless their maximum rated airflow exceeds 400 cfm, in accordance with current ASHRAE 62.2 standard-2010 | Minimize noise | |

| 7.8003.1 | | Lighting Upgrade | |
|-------------------------------|--|--|--|
| Topic | Plug Load | | |
| Subtopic | Lighting | | |
| Desired Outcome | Energy used for lighting reduced while maintaining adequate and safe lighting levels | | |
| Single-Family Homes | | | |
| Title | Specification(s) | Objective(s) | |
| 7.8003.1a Day lighting | Window coverings (e.g., blinds, shades, movable insulation) will be replaced or maneuvered to maximize useful daylight where appropriate | Reduce energy use without negative consequences (e.g., glare, unintentional heating) | |
| | Active and passive day lighting will be properly oriented, designed, and installed where appropriate | | |
| 7.8003.1b Selection | All bulbs, fixtures, and controls will be appropriate for the intended application (e.g., enclosed, orientation, dimmable, potential for breakage, indoor, and outdoor) | Provide improved lighting quality at lower energy use | |
| | All bulbs, fixtures, and controls will be selected to provide the brightness and light quality required in that application (e.g., task lighting, trip-and- fall hazards, nightlights) | Select equipment that will not be an unnecessary barrier to future technologies | |
| | Selected equipment should have the highest level of efficiency within a technology [e.g., compact fluorescent lamp (CFL), LED] | Avoid inferior products and unsatisfied occupants | |
| | All bulbs, fixtures, and controls will be ENERGY STAR® rated where applicable | | |
| | When possible, bulbs, fixtures, and controls will be selected that will facilitate the use of future lighting technologies (e.g., LEDs) | | |
| | When incandescent bulbs cannot be replaced or when occupant chooses not to replace, a dimmer will be selected | | |
| | Light/lamp wattage should not exceed rated wattage of fixture | | |
| | Bulb replacements will be chosen based on expected durability, light quality, and lifetime energy use of the bulb | | |
| | Controls to turn off lights when not needed (e.g., no one in room) will be provided | | |
| | | | |

| | | | |
|------------------------------|---|--|--|
| | All bulbs, fixtures, and controls will be UL-approved and installed in accordance with local code(s) and NFPA 70 National Electric Code | | |
| | Fluorescent light ballasts containing polychlorinated biphenyls (PCBs) will be replaced in accordance with the EPA's Healthy Indoor Environment Protocols for Home Energy Upgrades | | |
| Manufactured Housing | | | |
| Title | Specification(s) | Objective(s) | |
| 7.8003.1a Daylighting | Window coverings (e.g., blinds, shades, moveable insulation) will be replaced or maneuvered to maximize useful daylight where appropriate | Reduce energy use without negative consequences (e.g., glare, unintentional heating) | |
| | Active and passive daylighting will be properly oriented, designed, and installed where appropriate | | |
| 7.8003.1b Selection | All bulbs, fixtures, and controls will be appropriate for the intended application (e.g., enclosed, orientation, dimmable, potential for breakage, indoor and outdoor) | Provide improved lighting quality at lower energy use | |
| | All bulbs, fixtures, and controls will be selected to provide the brightness and light quality required in that application (e.g., task lighting, trip-and-fall hazards, nightlights) | Select equipment that will not be an unnecessary barrier to future technologies | |
| | Selected equipment should have the highest level of efficiency within a technology [e.g., compact fluorescent lamp (CFL), LED] | Avoid inferior products and unsatisfied occupants | |
| | All bulbs, fixtures, and controls will be ENERGY STAR rated where applicable | | |
| | When possible, bulbs, fixtures, and controls will be selected that will facilitate the use of future lighting technologies (e.g., LEDs) | | |
| | When incandescent bulbs cannot be replaced or when occupant chooses not to replace, a dimmer will be selected | | |
| | Power quality will be evaluated before new lighting is selected | | |
| | Light/lamp wattage should not exceed rated wattage of fixture | | |
| | | | |
| | | | |

| | | |
|--|--|--|
| | Bulb replacements will be chosen based on expected durability, light quality, and lifetime energy use of the bulb | |
| | Controls to turn off lights when not needed (e.g., no one in room) will be provided | |
| | All bulbs, fixtures, and controls will be UL-approved and installed in accordance with local code(s) and NFPA 70 National Electric Code | |
| | Fluorescent light ballasts containing polychlorinated biphenyls (PCBs) will be replaced in accordance with the EPA's Healthy Indoor Environment Protocols for Home Energy Upgrades | |

| 7.8102.2 | | Storage-Type Appliance |
|------------------------|---|-------------------------------|
| Topic | Water Heating | |
| Subtopic | Installation and Replacement | |
| Desired Outcome | Safe and reliable hot water source provided that meets occupant needs at lowest possible cost of ownership | |
| Note | The authority having jurisdiction may require that a licensed professional perform certain tasks outlined in this detail. | |

| Single-Family Homes | | |
|---|---|--|
| Title | Specification(s) | Objective(s) |
| 7.8102.2a Hazardous material removal | Health concerns in the removal and replacement of equipment (e.g., asbestos, other hazardous materials) will be identified | Remediate health hazards using EPA-certified contractors |
| | Written notification will be provided to occupants of the discovery of hazardous material, including contact information for regional EPA asbestos coordinator | |
| | Occupant will be asked to contract with an EPA-certified asbestos contractor to conduct abatement before equipment removal and replacement (occupant is responsible for abatement or remediation) | |
| 7.8102.2b Equipment removal | Accepted industry procedures and practices will be followed to: | Ensure the safety of the workers and occupants |

| | | |
|--|---|--|
| | Remove old water heater and associated components in accordance with 2012 IRC R105.1 or authority having jurisdiction | Preserve integrity of the building |
| | Seal any unused chimney openings and penetrations in accordance with 2012 IRC N1102.4.1.1 or authority having jurisdiction | |
| | Remove unused oil tank, lines, valves, and associated equipment in accordance with 2012 IRC M2201.7 or authority having jurisdiction | Remove old equipment in a timely and efficient manner |
| | All work shall be completed by a licensed plumbing professional where required by the authority having jurisdiction and installed to industry-accepted standards | |
| 7.8102.2c New equipment installation | New water heater and associated components will be installed to accepted industry standards, in accordance with the 2012 IRC and manufacturer specifications | Ensure the safety of the workers and occupants |
| | The system will be installed to be freeze resistant | Preserve integrity of the building |
| | Any existing water leaks will be repaired before installation begins | Remove old equipment in a timely and efficient manner |
| | Any penetrations to the exterior of the home created by the installation of the equipment will be sealed | |
| 7.8102.2d Emergency drain pan | An emergency drain pan will be installed with sides that extend a minimum of 4" above floor if leakage would cause damage to the home and in accordance with P2801.5 of the 2012 IRC | Collect and safely dispose of water escaping from the storage tank |
| | A ¾" drainline or larger will be connected to tapping on pan and terminated in accordance with P2801.5.2 of the 2012 IRC | |
| 7.8102.2e Expansion tank | A potable water expansion tank will be installed on the cold water side | Protect the storage tank from expansion |
| | A direct connection with no valves between the storage tank and expansion tank will be installed in accordance with the 2012 IRC, authority having jurisdiction, and according to manufacturer specifications | |
| 7.8102.2f Temperature and pressure relief valve | Correct temperature and pressure relief valve will be installed in compliance with P2803 of the 2012 IRC and according to manufacturer specifications | Discharge excessive energy (pressure or temperature) from storage tank to safe |

| | | |
|--|---|---|
| | Temperature and pressure relief valve discharge tube will be installed in accordance with P2803.6.1 of the 2012 IRC | location |
| 7.8102.2g Dielectric unions | Dielectric unions will be installed in accordance with the 2012 IRC, authority having jurisdiction, and according to manufacturer specifications | Break the stray voltage electrical circuit through the storage tank |
| 7.8102.2h Backflow prevention | Backflow prevention will be installed in accordance with manufacturer specifications and all applicable codes | Protect water supply from contamination |
| 7.8102.2i Thermal efficiency | If additional tank insulation is installed, it will be rated a minimum of R-11 and will be installed to manufacturer specifications | Reduce standby loss from near tank piping and storage tank |
| | If additional insulation is installed, it will be installed based on fuel type, making sure not to obstruct draft diverter, pressure relief valve, thermostats, hi-limit switch, plumbing pipes or elements, and thermostat access plates | Ensure insulation does not make contact with flue gas venting |
| | The first 6' of inlet and outlet piping will be insulated in accordance with manufacturer specifications | |
| | <u>Combustible P</u> pipe insulation must remain <u>maintain a minimum clearance of 3" 6"</u> from gas water heater <u>draft hood and/or single wall metal pipe</u> vent . <u>Clearance from vent such as "B" vent should be maintained per vent manufacturer's specifications.</u> | |
| | Heat traps will be installed on the inlet and outlet piping where not provided by manufacturer | |
| | | |
| 7.8102.2j Fuel supply | Electric or fossil fuel supply components will be installed to accepted industry standards as per NFPA 31 and 54, or NFPA 70 National Electric Code (NEC) for electric components, or authority having jurisdiction | Provide sufficient fuel to the water heater, burner, or element |
| 7.8102.2k Discharge temperature | Discharge temperature will be set not to exceed 120° or as prescribed by local code | Ensure safe hot water supply temperature to fixtures |

| | | |
|--|--|---|
| 7.8102.2l Commissioning of system | The following will be checked once the system has been filled and purged: | Ensure safe system function |
| | Safety controls | Keep cost of ownership as low as possible |
| | Combustion safety and efficiency | |
| | Operational controls | |
| | Fuel and water leaks | |
| | Local code requirements | |
| | Commissioning will be in compliance with manufacturer specifications and relevant industry standards | |
| 7.8102.2m Occupant safety | Carbon monoxide (CO) alarms will be installed in each dwelling in accordance with ASHRAE 62.2 and authority having local jurisdiction | Ensure occupant life safety; CO alarms are designed to detect levels at which occupants might become unable to evacuate |
| | Occupant will be provided information regarding the health effects and risk of high CO concentrations as well as a list of monitors that can provide more detail regarding CO levels | |
| 7.8102.2n Occupant education | Completed work will be reviewed | Ensure occupant is informed of the safe, efficient operation and maintenance of the system |
| | Occupants will be educated on the safe and efficient operation and maintenance of the system, including: | |
| | Adjustment of water temperature and target temperature in accordance with local code | |
| | Periodic drain and flush | |
| | Expansion tank and backflow preventer (no occupant maintenance required) | |
| | Periodic inspection, maintenance, or replacement | |
| | | |
| Manufactured Housing | | |
| Title | Specification(s) | Objective(s) |

| | | |
|---|---|--|
| 7.8102.2a Hazardous material removal | Health concerns in the removal and replacement of equipment (e.g., asbestos, other hazardous materials) will be identified | Remediate health hazards using EPA-certified contractors |
| | Written notification will be provided to occupants of the discovery of hazardous material, including contact information for regional EPA asbestos coordinator | |
| | Occupant will be asked to contract with an EPA-certified asbestos contractor to conduct abatement before equipment removal and replacement (occupant is responsible for abatement or remediation) | |
| 7.8102.2b Equipment removal | Accepted industry procedures and practices will be followed to: | Ensure the safety of the workers and occupants |
| | Remove old water heater and associated components in accordance with 2012 IRC R105.1 or authority having jurisdiction | Preserve integrity of the building |
| | Seal any unused chimney openings and penetrations in accordance with 2012 IRC N1102.4.1.1 or authority having jurisdiction | |
| | Remove unused oil tank, lines, valves, and associated equipment in accordance with 2012 IRC M2201.7 or authority having jurisdiction | Remove old equipment in a timely and efficient manner |
| | All work shall be completed by a licensed plumbing professional where required by the authority having jurisdiction and installed to industry-accepted standards | |
| 7.8102.2c New equipment installation | New water heater and associated components will be installed by a licensed contractor to accepted industry standards, in accordance with the 2012 IRC and manufacturer specifications | Ensure the safety of the workers and occupants |
| | The system will be installed to be freeze resistant | Preserve integrity of the building |
| | Any existing water leaks will be repaired before installation begins | Remove old equipment in a timely and efficient manner |
| | Any penetrations to the exterior of the home created by the installation of the equipment will be sealed | |
| 7.8102.2d Emergency drain pan | An emergency drain pan will be installed with sides that extend a minimum of 4" above floor if leakage would cause damage to the home and in accordance with P2801.5 of the 2012 IRC | Collect and safely dispose of water escaping from the storage tank |

| | | |
|--|--|---|
| | A ¾" drain line or larger will be connected to tapping on pan and terminated in accordance with P2801.5.2 of the 2012 IRC | |
| 7.8102.2e Expansion tank | A potable water expansion tank will be installed on the cold water side | Protect the storage tank from expansion |
| | A direct connection with no valves between the storage tank and expansion tank will be installed in accordance with the 2012 IRC, authority having jurisdiction, and according to manufacturer specifications | |
| 7.8102.2f Temperature and pressure relief valve | Correct temperature and pressure relief valve will be installed in compliance with P2803 of the 2012 IRC and according to manufacturer specifications | Discharge excessive energy (pressure or temperature) from storage tank to safe location |
| | Temperature and pressure relief valve discharge tube will be installed in accordance with P2803.6.1 of the 2012 IRC | |
| 7.8102.2g Dielectric unions | Dielectric unions will be installed in accordance with the 2012 IRC, authority having jurisdiction, and according to manufacturer specifications | Break the stray voltage electrical circuit through the storage tank |
| 7.8102.2h Backflow prevention | Backflow prevention will be installed in accordance with manufacturer specifications and all applicable codes | Protect water supply from contamination |
| 7.8102.2i Thermal efficiency | If additional tank insulation is installed, it will be rated a minimum of R-11 and will be installed to manufacturer specifications | Reduce standby loss from near tank piping and storage tank |
| | If additional insulation is installed, it will be installed based on fuel type, making sure not to obstruct draft diverter, pressure relief valve, thermostats, hi-limit switch, plumbing pipes or elements, and thermostat access plates | Ensure insulation does not make contact with flue gas venting |
| | The first 6' of inlet and outlet piping will be insulated in accordance with manufacturer specifications | |
| | <u>Combustible P</u> pipe insulation must <u>maintain a minimum clearance of 6"</u> remain 3" from gas water heater vent <u>draft hood and/or single wall metal pipe. Clearance from vent such as "B" vent should be maintained per vent manufacturer's specifications</u> | |
| | Heat traps will be installed on the inlet and outlet piping where not provided by manufacturer | |

| | | |
|--|---|---|
| 7.8102.2j Fuel supply | Electric or fossil fuel supply components will be installed to accepted industry standards as per NFPA 31 and 54, or NFPA 70 National Electric Code (NEC) for electric components, or authority having jurisdiction | Provide sufficient fuel to the water heater, burner, or element |
| 7.8102.2k Discharge temperature | Discharge temperature will be set not to exceed 120° or as prescribed by local code | Ensure safe hot water supply temperature to fixtures |
| 7.8102.2l Commissioning of system | The following will be checked once the system has been filled and purged: | Ensure safe system function |
| | Safety controls | Keep cost of ownership as low as possible |
| | Combustion safety and efficiency | |
| | Operational controls | |
| | Fuel and water leaks | |
| | Local code requirements | |
| | Commissioning will be in compliance with manufacturer specifications and relevant industry standards | |
| 7.8102.2m Occupant safety | Carbon monoxide alarms will be installed in each dwelling in accordance with ASHRAE 62.2 and authority having local jurisdiction | Ensure occupant life safety; CO alarms are designed to detect levels at which occupants might become unable to evacuate |
| | Occupant will be provided information regarding the health effects and risk of high CO concentrations, as well as a list of monitors that can provide more detail regarding CO levels | |
| | Ambient CO to be maintained at or under 10 ppm or within acceptable limits as comparable to outside concentrations | |
| 7.8102.2n Occupant education | Completed work will be reviewed | Ensure occupant is informed of the safe, efficient operation and maintenance of the system |
| | Occupants will be educated on the safe and efficient operation and maintenance of the system, including: | |
| | Adjustment of water temperature and target temperature in accordance with local code | |
| | Periodic drain and flush | |
| | Expansion tank and backflow preventer (no occupant maintenance required) | |
| | Periodic inspection, maintenance, or replacement | |
| | | |